

Tender for Air conditioning works for Indian Bank's proposed Inspection Centre and Staff Training Centre at 3rd Floor, Jenny Plaza, 5-F, Bharathiyar Salai, Cantonment, Trichy – 620 001

ANNEXURE-I

TENDER DATE	30.01.2019	LAST DATE OF TENDER SUBMISSION	21.02.2019
PRE-BID MEETING DATE	08.02.2019	PRE-BID CLARIFICATION DATE	15.02.2019
SI.No	Description	Bidder Query	Bank's Reply
		As per Tender (Technical / Price Bid)	
		Clause	Page
		Description	

General			
SI.No	Description	Clause	Page
01	The proposed AC units are Inverter type or Non-inverter type	-	-
02	Type of refrigerant to be used	-	-
03	Type of material to be used for fabrication of ventilation duct	-	-
04	For outdoor units, whether compressor other than the type mentioned in the tender can be used.	-	-
05	When to submit the performance guarantee	-	-
06	What is the procedure to submit the Bid	-	-

The proposed AC for the subject work is Non-inverter type.

Refrigerant used should be of Eco-friendly type.

The material of ventilation duct should be Aluminium sheet.

Tender specification holds good.

For the subject work, The tenderer has to submit 5% of the tendered value of work as performance guarantee (**format given in Appendix IV page no. 66 of 76**) for a period of 2 years in the form of irrevocable bank guarantee from any scheduled bank in the form prescribed or fixed deposit receipt, within 15 days of the Virtual Completion, before settlement of final bill.

Technical bid (all pages signed & stamped) along with EMD and tender fee as prescribed in the tender should be in 1st Cover and 2nd Cover should contain only price bid. Both 1st



									& 2 nd cover should be placed in 3 rd cover.
07	-								The technical bid will be opened as per the date given in tender. Upon scrutiny of the technical bids as per the eligibility criteria, opening of price bids will be informed only to qualified bidders.
08	-								Local representative shall be available to attend the calls from Bank at Trichy for any kind of repair/Maintenance works on the AC installation. In this regard, proof of availability of representative should be submitted.
09									Priority shall be given to the makes specified in the tender. For other if any, prior approval of Bank / Architect is required.



५