

PRE BID MEETING (07.01.2022) QUERIES

WORK: 'Supply, installation, testing, commissioning and maintenance of Two lifts (10 passenger each) after dismantling existing lifts at indian bank, Krest building, no. 2, Jehangir street, chennai-01'.

Sl.no	Query raised	Details of query	Department response and changes required in tender, if any
1		The existing lift is having the SS partition between the two lift which is available in parts and not single full sheet partition Whether the same is to be installed and cost of the installation of the full sheet partition will be borne by which party.	The existing partition of SS sheet shall be continued and they shall not be removed during the dismantling of the lift. Any damage of the existing partitions shall be made good by the contractor at their own cost.

4