

INDIAN BANK

TENDER DOCUMENT

FOR

INTERIOR FURNISHING, ELECTRICAL, LAN, UPS
SYSTEM & AIR CONDITIONING WORK.

AT

MODI NAGAR STATION ROAD BRANCH , GHAZIABAD.

Date of Issue : - 13.09.2024.

Date of Submission : - 20.09.2024. Up to 02:30 PM.

ARCHITECTS

ARCH DESIGN ARCHITECTS

34, Ganapati Niwas,
Civil Lines, Bulandshahr,
Uttar Pradesh- 203001

E-Mail: - archdes12@gmail.com

Mobile: + 91- 9899227440, 9412857600.

SECTION – I

INVITATION TO TENDERS

- 1.0 Sealed tenders on item rate bases are invited in the prescribed form by the Zonal Manager, Indian Bank, Zonal Office, D-211/2, Sector-61, Noida-201301, Uttar Pradesh. for Interior Furnishings, Electrical, LAN, UPS System & AC Work at Modi Nagar Brach Ghaziabad.

Tender No.	:	IB/ZO/NO/MN/UP/01/2024-25
Name of Work	:	Interior Furnishing, Electrical, Data/Voice, Air-conditioning work
Earnest Money	:	30,000/-in the Form of DD
Time of Completion	:	60 Days.

- 1.1 The work as detailed in this tender shall be executed and completed in all respect with in a period of 60 Days from the date of written order to commence the work in accordance with the tender documents, Instruction to tenders, technical specification, Schedule of Quantities, Condition of contract, Schedules and drawings, to the satisfaction of Architect / Employer.
- 1.2 The Tender(s) are required to deposit Rs. 30,000/-as Earnest Money along with the tender document in the form of crossed Demand Draft only favoring Indian Bank, Zonal Office, Noida and payable at Indian Bank, Zonal office, Noida.
- The Earnest Money will be refunded without any interest to the unsuccessful tenders after a decision is taken regarding award of contract.
- 1.3 Tenders filled in the prescribed form in sealed covers and super scribed with the name of work, Tender No. IB/ZO/NO/MN/UP/01/2024-25 must be submitted to the Zonal Manager, Indian Bank, Zonal Office, D-211/2, Sector-61, Noida-201301, Uttar Pradesh, not later than 02:30 PM on 20.09.2024. Tenders will be opened on the same day at 03:30 P.M. in the presence of tenderers or their representatives. Any correction/alteration made using “Correcting Fluid” will not be accepted and tender will be liable to be rejected.
- 1.4 Tender document can be downloaded from Bank’s website i.e. <https://www.indianbank.in/tender/#navtenders> from 13.09.2024 to 20.09.2024 up-to 01:30 PM. Same to be submitted to Indian Bank, Zonal Office, Noida with Rs.1,000/- Demand Draft (Non-Refundable) as tender fees, addressed to Indian Bank, Zonal Office, Noida. Without the said DD, the bid will be summarily rejected.
- 1.5 **MSME EXEMPTION:** - Contractor carrying a valid MSME certificate will be exempted from submitting EMD. However, if the contractor becomes L1 and work is offered to them he/they will have to submit the required EMD with their acceptance of work within Seven (07) working days.
- MSME contractor will not be exempted from tender fees. The tender fee of Rs. 1000/- is mandatory for all the bidders.
- 1.6 The drawings are enclosed along with set of specifications.
- 1.7 Rate must be quoted for complete work at site inclusive of all costs, charges, taxes etc but excluding GST on WCT. All duties, E.S.I. charges etc. as applicable at Noida or state sales Tax, Octopi, Royalties etc. on works and materials required for use in the execution of this project shall be entirely borne and payable by the contractor and the Employer will not entertain any claim whatsoever in this respect except GST on WCT.
- 1.8 The tenders shall remain valid for acceptance by the Employer, for a period of 3 month from the date of opening of tender.

1.9 Total Deposit shall comprise of:

- a) Earnest Money Deposit (Adjustable without interest).**
- b) Tender Fees (Non-refundable).**

1.9.1 The retention percentage (i.e. deduction from interim bill) shall be 10% of the gross value of each interim bill.

1.9.2 Total retention amount is refunded to the contractor subject to the following: -

- (1) Issue of virtual completion certificate by the Architect / Premises department.**
- (2) Contractor should remove his material, equipment's, labor force, temporary shed stores etc. from the site**

The retention money may be refunded without any interest 7 (Seven) days after the end of defects liability period of ONE YEAR provided, he has satisfactorily carried out all the work and attended to all defects in accordance with the conditions of the contract.

1.9.3 Earnest money of the successful tender will be liable to be forfeited in the event of refusal or delay on his part in deposit initial security deposit and signing the agreement within 7 (seven) days, of the issue of letter of award of the work.

1.9.4 Tender documents duly filled and signed by the tender shall be submitted for the work.

1.9.5 The Indian Bank and their approved architect, do not bind itself to accept the lowest or any tender, or to assign any reason thereof and also reserves the right of accepting the whole or part of the tender and the tender shall in such an event be bound to perform the contract at the same rates quoted in the tender for the various items of the work.

1.9.6 Canvassing in any form in connection with the tender is strictly prohibited and the tenders submitted by the contractors who resort to canvassing from shall be liable for rejection.

1.9.7 The tendering firms, in case the tender is a partnership firms, shall submit the tender signed by all the partners. In the event of absence of any partner, it must be signed on his behalf by a person holding power of attorney authorizing him to do so and such power of attorney be attached along with the tender.

APENDIX SHOWING IMPORTANT SCHEDULES

1. **NAME OF WORK** : Interior Furnishing, Electrical, LAN, UPS Wiring & AC work at Modi Nagar Branch, Ghaziabad, Uttar Pradesh
2. **SIGNING THE AGREEMENT** : Within 07 Days of the issue of letter of intent / order.
3. **DATE OF COMMENCEMENT OF WORK** : Within 07 Days of issue of letter of intent / order or the day on which site is handed over to contractor.
4. **PERIOD OF COMPLETION** : 60 Days from the tender date of commencement of work.
5. **LIQUIDATED DAMAGES** : 2% of contract amount per week of delay subject to the max. of 10% of the accepted contracted sum.
6. **PERIOD AND VALUE OF RUNNING / ON ACCOUNT BILL.** : 75% of amount within 7th days after date of receipt of architect certificate and balance within 21days.
7. **INCOME TAX DEDUCTION** : As prevailing rate from each bill.
8. **DEFECTS LIABLITY PERIOD** : 12 Months after completion of work.
9. **PERIOD OF FINAL MEASUREMENT** : 2 Weeks after virtual completion of work.

SECTION – 2
INSTRUCTION TO TENDERS.

INSTRUCTION TO TENDERS.

2.1 The tender shall examine carefully all the tender documents consisting of: –

- Invitation to Tenders.**
- Instruction to Tenders.**
- Form of Agreement.**
- General Conditions of Contract.**
- Schedule of Quantities.**

These shall form part of the Agreement.

The tender is advised to visit and inspect the site at his own cost and responsibility and to secure all necessary information which may be required for completing the tender. Ignorance of site conditions can't be an excuse for non-performance of the contract. All costs, charges and expenses that may be incurred by the tender in connection with the preparation of his tender shall bear by him and the employer / architect does not accept any liability whatsoever in this regard.

- 2.2 Time is the essence of the contract and the tenders are required to complete the work in all respects within the stipulated time of completion and handover the same, complete in all respects to the satisfaction of the architect.**
- 2.3 The tender should contain not only the rates but also the value of each item of work entered in the prescribed column of the B.O.Q. and all the items should be totaled up in order to show the aggregate value of the entire tender. The rates quoted by the tenders should be expressed accurately both in words and figures so that there is no discrepancy. All corrections in the tender shall be duly attested by initials of the tender, corrections, if not attested may entail rejection of tender. The rates quoted by the tenders in word in item rate tender will be the basis (and not the amounts in case of discrepancies) in finalizing the tender.**
- 2.4 It shall be clearly understood that the rates quoted in the tender are to be, for complete work at site, as per instructions to Tenders, conditions of contract, specifications and drawings, addenda referred to therein and also, for all such works as are necessary for the proper completion of the contract, although specifications thereof may not have been made in the specifications or drawings or tender documents. The rates shall be firm and shall not be subject to cost escalation on account of labor, material and labor conditions or any other reason whatsoever.**
- 2.5 The tenders shall use only the form issued with this tender to fill up the rates.**
- 2.6 Every page of the tender shall be signed on the left-hand side bottom corner and any tender not so complied with is liable to be treated as defective & liable to be rejected.**
- 2.7 In the event of a tender being selected for acceptance. The Indian Bank will inform the tender for the specification and other documents for the acceptance with tender. The successful tender shall also deposit the required amount of the security money within the prescribed time and if the tender fails to deposit the required amount of the security money within the prescribed period, Indian Bank may reject the tender.**
- 2.8 The successful tender will be notified about the acceptance of his tender by the Employer and he will have to deposit balance amount initial security and executed agreement within 7 (Seven) days thereof, failing which his tender would be liable to rejection with forfeiture of the Earnest Money.**
- 2.9 The tender shall fill up the complete form of article of agreement before submission of tender. Failure to comply may entail rejection of the tender.**
- 2.10 The contractor will be governed by the Indian contract act, Indian sale of goods act and all other relevant laws. All payments due to the contractor under the contract will be made in Indian rupee currency.**
- 2.11 The rate quoted shall be for complete work at site and should be inclusive of incidentals necessary for carrying out the work. The rates shall be inclusive of sales tax if applicable at Noida for work contract, central or state sales tax, octroi duty, royalty, ESI or any other tax or duty levied by any government or public bodies**

excluding GST on WCT. The rate shall be firm and shall not be subject to cost escalation of labor, material and exchange variations, labor conditions and other conditions whatsoever.

- 2.12 A schedule of approximate quantities for various items accompanies this tender. It shall be clearly understood that neither the architect nor the employer will accept any responsibility for the correctness or completeness of this schedule in respect of item and quantities and this schedule is liable to alternations by omission, deduction or addition at the discretion of the employer in consultation with the architect without violating the items of the contract.
- 2.13 The contractor must produce latest income tax clearance certificate along with this tender.
- 2.14 Form of 'Tender of works' contained in section –3 shall be completed along with submission of tender. In case of failure to do so the tender is liable to rejection.
- 2.15 The employer does not bind itself to accept the lowest or any tender or to assign any reason thereof and also reserves the right of accepting the whole or part of the tender. The part acceptance will not violate the terms and conditions of the contract and will execute the work at the specified rates without any extra charges or compensation.
- 2.16 Income tax deductions will be made as per the prevailing rates from the contractor's on account bills.
- 2.17 No mobilization advance or secured advance is to be allowed to the contractor.
- 2.18 Power and water connection, if required, has to be arranged by the contractor only.
- 2.19 The Contractor should have been empaneled from Indian Bank Delhi & NCR Region.
- 2.20 The contractor/firm should have valid GST registration number for the particular trade of work.

SECTION - 3

FORWARDING LETTER

FROM: _____

To: _____

Ref.: _____

Dear Sir,

1. With reference to the tender invited by you, I/ we hereby offer to perform, provide, execute and complete the works in conformity with conditions of contract, drawings and specifications for the respective items of schedule of quantities attached hereto.
2. I/ we have satisfied myself / ourselves as to the location and prevailing conditionings of the site, and have read carefully the articles of agreement, condition of contract, specification, general and special conditions, technical specifications etc., and I/We understand that the works are to be completed within 60 Days from the date of commencement and fully understand that the time will be the essence of the contract.
3. I/We enclosed a demand draft for Rs.19,000/- drawn on Indian Bank payable at favor of the Indian Bank, Zonal Office, Noida as earnest money and fully understand that this amount will not bear any interest.
4. I/We agree to keep the offer for 3 months from the date of opening the tender.
5. Should this tender be accepted in whole or in part, I/We hereby agree to abide by and fulfill and the terms and conditions annexed hereto. I/We fail to commence the work specified in tender documents; I/We agree that my / our earnest money shall stand for-feinted absolutely to the Employer otherwise the said Earnest money shall be retained by the Employer towards security deposit (retention money).
6. All the terms and conditions contained in the notice Inviting Tenders, Conditions of Tenders, General conditions of contract, specifications for execution of the work, additional conditions and the agreement etc. constituting the tender documents have been fully read by me/us and explained to me/us and I/We hereby accept the same and sign hereunder in token of their acceptance.
7. We are further enclosing herewith the following documents: -
 - i) Partnership Deed. Article of Association and power of Attorney. We agree that no change will be made in these documents without prior approval of the Indian Bank.

- ii) Tender documents duly signed along with detailed program and targets of completion of each items work.
 - iii) Detail of deployment of manpower, machinery, plant and equipment.
 - iv) Latest I.T.C.C
 - v) Demand Draft No. _____ Date _____ Drawn
-

Name of the partners / Directors Of the firm

1)

2)

Date: - _____

Yours Faithfully

Witness: - _____

Address: - _____

Name & Sign. Of Tenderer(s) Office

Occupation: - _____

Stamp and Seal of Tenderer(s) Office

SECTION – 4
AGREEMENT

AGREEMENT

This agreement made at _____ Day of _____, between the Zonal Manager, Indian Bank, Zonal Office, D-211/2, Sector-61, Noida-201301, Uttar Pradesh. (Hereinafter called the Employer which expression shall include their heirs, executors, administrators and assignees) of the one part and M/S _____ (herein after called the 'Contractor') of the other part. Whereas the employer is desirous that work should be executed as per drawings and specifications describing the work to be done, to be prepared by their approved Architects and WHEREAS the said drawings, the specifications and the price schedule of quantities have signed by or on behalf of the parties hereto and WHEREAS the contractor has agreed to execute upon and subject to the conditions set forth herein and the said priced schedule of quantities at the respective rates mentioned in the priced schedule of quantities , which as part of the tender document.

And WHEREAS the contractor has deposited Rs. 30,000/-as the Earnest Money with the Employer, which shall become part of security deposit to be until the expiry of the Defect liability period for the due observance of the contract.

NOW THIS AGREEMENT WITNESSETH AS FOLLOWS:

1. In consideration of the said contract, payments to be made to the said conditions execute and complete the works shown upon the said Drawings and such further detailed drawings as may be furnished to him by the said Architects and described in the specifications and the said priced schedule of quantities.
2. The employer shall pay the contractor such sums as shall become payable hereunder at the times and in the manner specified in the said conditions.
3. The said contract comprised the building above mentioned and all subsidiary works connect there within the same site as may be ordered to be done from time to time by the said Architects even, through such works may not be shown on the Drawings or described in the said specification or the priced schedule of quantities.
4. The Employer through Architect reserves to himself the right of altering the drawing and nature of the work and adding to or omitting any items of works, check of measurement, payment certificate, variation arising in view of change of scope of work and approval of rates of extra substituted items. The decision of the Employer shall be final and binding in this regard.
5. The Employer in consultation with the Architect reserves the right to exercise control on quality of work, check of measurement, payment certificate, variation arising, in view of change of scope of work and approval of rates of extra submitted items. The decision of the Employer shall be final and binding this regard balance retention money being deducted from my /our bills in accordance with the conditions of contract.
6. The following documents shall be deemed to form and constructed as part of this agreement along with the amendments, negotiated and confirmed in various subsequent latter exchanged as mentioned hereinafter and parties hereto will respectively abide by and submit themselves to the conditions and stipulations and perform the agreement on their parts respectively in such conditions contained.
 - i) Invitation to Tender.
 - ii) Instruction to Tenders.
 - iii) General Conditions of the contract.
 - iv) Technical Specifications.

- v) **Schedule of Quantities.**
- vi) **Employer letter date _____ / _____ / _____ to the contractors awarding the contract.**
- vii) **Contractors letter date _____ / _____ / _____ to the Employer in acceptance of the award of contract.**

- 7. **All disputes arising out of or in any way connected with the agreement shall be deemed to have arisen at New Delhi only, the court in New Delhi shall have jurisdiction to determine the same.**
- 8. **The several parts of this contract have been read to us and fully understood by us.**

Witness our hand this..... day of2024.

SIGNED BY THE SAID (EMPLOYED)

IN THE PRESENCE OF

ADDRESS

.....

SIGNED BY THE SAID (CONTRACTOR)

IN THE PRESENCE OF

ADDRESS

.....

SECTION – 5

GENERAL CONDITION OF CONTRACT

Except where provided for in the description of the individual items in the schedule of quantities and in the specifications and conditions laid down hereinafter and in the drawing. The work shall be carried out as per standard specifications and under the direction of employer / Architect.

1. INTERPRETATION

In construing these conditions, the specifications, the schedule of quantities, tender and agreement, the following words shall have meant herein assigned to them except when the subject or context otherwise required.

- i) **Employer:** The term employer shall mean Indian Bank having their head office at 66, Rajaji Salai, Chennai and any of its employee's representative authorized on their behalf.
- ii) **Architect:** The term architect shall mean the approved architects of Indian Bank or in the event of his / their ceasing to be the architect for the purpose of this contract such other person/s as the employer shall nominate for the purpose.
- iii) **Contractor:** The term contractor shall mean Company, firm or the party to whom the Contract is awarded and shall include his / their legal representative(s) or successor(s).
- iv) **Site:** Shall mean the places or buildings envisaged by the employer where the work is to be executed or carried out.
- v) **Site Engineer:** The bank may appoint the site engineer. The bank may also determine the number of site engineer and the supporting staff at site office to assist them and also whether the site engineer shall be temporary or permanent. As far as possible, the site engineer should assume charge of his post before the contractor reports on site of work. Where more than one site engineer is appointed, one of them shall be designated as senior site engineer by the premises department and the other site engineer shall be reporting to the senior site engineer.
- vi) **Drawings:** The work is to be carried out in accordance with drawings, specifications, the schedule of quantities and any further drawings which may be supplied or any other instruction, which may be given by the employer during the execution of work.

All drawings relating to work given to the contractor together with a copy of schedule of quantities are to be kept at site and the employer / Architect shall be given access to such drawings or schedule of quantities whenever necessary.

In case any detailed drawings and necessary contractor shall prepare such detailed drawing and / or dimensional sketches therefore and have it confirmed by the employer / Architect prior to taking up such works.

The contractor shall ask in writing for any clarification on matters occurring anywhere in drawings, specifications and schedule of quantities or to additional instructions at least 10 days ahead from the time when it is required for implementation so that the employer may be able to decision thereon.
- vii) **"The Works"** shall mean the work or works to be executed or done under this contract.
- viii) **"Act of Insolvency"** shall mean any act as such as defined by the presidency town's insolvency act or provisional insolvency act or any amending statutes.
- ix) **"The schedule of quantities"** shall mean the schedule of quantities as specified and forming part of this tender.
- x) **"Priced schedule of quantities"** shall mean the schedule of quantities duly priced with the accepted quoted rates of the contractor.

2. SCOPE

The work consists of Interior furnishing, Electrical, LAN, UPS System & Air Conditioning work at MODI NAGAR STATION ROAD BRANCH , GHAZIABAD, Uttar Pradesh. In accordance with the “drawings” and “Schedule of quantities”. It includes furnishing all material, labor, tools and equipment and management necessary for the incidental to the construction and completion of the work. All works, during its progress and upon completion, shall conform to the lines, elevations and grades as show on the drawings furnished by the employer / architects. Should any detail essential for the efficient completion of the work to be omitted from the drawings and specifications, it shall be

responsibility of the contractor to inform the employer / architects and to furnish and install such detail with employer’s / architect’s concurrence, so that, upon completion of the proposed work, the same will be acceptable and ready for use.

Employer/ Architect may in their absolute discretion issue further drawings and / or written instructions, details, directions and explanations, which are hereafter collectively referred to as “The Employer’s / Architect’s instructions in regard to:

- a) The variation and modification of the design quality or quantity of works or the addition or omission or substitution of any work.
- b) Any discrepancy in the drawings or between the schedule of quantities and / or drawings and / or specification.
- c) The removal from the site of any defective material brought thereon by the contractor and the substitution of any other material thereof.
- d) The demolition removal and / or re-execution of any work executed by the contractor/s.
- e) The dismissal from the work of any persons employed thereupon
- f) The opening up for inspection of any work covered up.
- g) The rectification and making good of any defects under clauses hereinafter mentioned and those arising during maintenance period (retention period)

The Contractor shall forthwith comply and duly execute any work comprised in such employer / Architect’s Instructions provided always that verbal instructions, directions and explanations given to the contractor or his representative upon the works by the employer / Architects shall, if involving a variation, be confirmed in writing to the Contractor within seven days. No work, for which rates are not specifically mentioned in the priced schedule of quantities, shall be taken up without written permission of the employer / architect. Rates of items not mentioned in the priced schedule of quantities shall be fixed by the employer in consultation with the architects as provided in clause ‘variation’.

Regarding all factory-made products for which ISI marked products are available, only products bearing ISI marking shall be used in the work.

3. TENDER SHALL VISIT THE SITE

Intending tender shall visit the site and make him thoroughly acquainted with the local site condition. Nature and requirement of the works, facilities of transport condition effective labor and materials, access and storage for material and removal of rubbish. The tender shall provide in their tender for cost of carriage, height and other charges as also for any special difficulties and including police restriction for transport etc. for proper execution of work as indicated in the drawings. The successful tender will not be entitled to any claim of compensation for difficulties faced or losses incurred on account of any site condition which existed before the commencement of the work or which in the opinion of the employer / architects might be deemed to have reasonably been inferred to be existing before commencement of work.

4. TENDERS

The entire set of tender paper issued to the tender should be submitted fully priced also signed on the last page together with initials on every page. Initial / signature will indicate the acceptance of the tender paper by the tender.

The schedule of quantities shall be filled in as follows: -

- i) The rate column to be legibly filled in ink in both English figures and words.
- ii) Amount column to be filled in for each item and the amount for each subhead as detailed in the "Schedule of Quantities".
- iii) All corrections to be initialed.
- iv) The rate column for alternative items shall be filled up.
- v) The "Amount" column for alternative items of which the quantities are not mentioned shall not be filled up.
- vi) In case of any error / omissions in the quoted rates, the rates given in the tender marked "Original" shall be taken as correct rates.

No modifications, writing or corrections can be made in the tender papers by the tender but may at his option offer his comments or modifications in a separate sheet of paper attached to the original tender papers.

The employer reserved the right to reject the lowest or any tender and also to discharge any or all of the tenders for each section or to split up and distribute any item of work to any specialist firm or firms, without assigning any reason.

The tenders should not that tender is strictly on the item rate basis and their attention is drawn to the fact that the rates for each and every item should be correct, workable and self-supporting. It called upon by the employer / architects detailed analysis of any or all the rates shall be submitted. The employer / architect shall not be bound to recognize the contractor's analysis.

The work will be paid for as "measured work" on the base of actual work done and not as "lump sum" contract.

All items of work described in schedule of quantities are to be deemed and paid as complete work in all respects and details including preparatory and finishing work involved, directly related to and reasonably detectable from the drawings, specifications and schedule of quantities and no further extra charge will be allowed in this connection. In the case of lump sum charge in the tender in respect of any item of works the payments of such items of work will be made for the actual work done on the basis of lump sum charges as assessed by the employer / architect.

The employer has power to add to, omit from any work as shown in drawings, or described in specifications or included in schedule of quantities and intimate the same in writing, but no addition, omission or variation shall be made by the contractor without authorization from the employer. No variation shall vitiate the contract.

The tender shall note that his tender shall remain open for consideration for a period of 3 months from the date of opening of the tender.

5. AGREEMENT

The successful contractor required to sign agreement as may be drawn up to suit local conditions and shall pay for all stamp and legal expenses, incidental thereto.

6. GOVERNMENT AND LOCAL RULES

The contractor shall confirm to the provisions of all local bye-laws and acts relating to work and to the regulations etc. of the govt. and the local authorities and of any company with whose system the structure is proposed to be connected. The contractor shall give all notices required by said act, rules, regulations and bye-laws etc. and pay all fees payable to such authority/ authorities for execution of work involved. The cost if any shall be deemed to have been included in his quoted rates, taking into account all liabilities for licenses, fees for footpath

encroachment and restoration etc. and shall indemnify the employer against such liabilities and shall defend all actions arising from such claim or liabilities.

7. TAXES AND DUTIES

The tender must include in their tender prices quoted for all duties royalties, excise and sales tax or any other taxes or local charges if applicable, excluding GST on WCT No extra claim on this account will in any case be entertained.

8. PROVISIONAL SUM (P.S.)

All provisional sums described in the schedule of quantities as P.S. shall be exclusively allotted to the purchase of material and not for any handling and fixing to be done by the contractor. Such cost of handling and fixing with profit (including transport charges if required) shall be separately included in the contract price as described in the schedule of quantities. The disposal of the amount cover under this head will be absolutely at the discretion of the employer. Contractor is to make payments for these materials to the supplier on certificate or order issued by the employer / architect and release them through his bills from the employer.

9. QUANTITIES OR WORK TO BE EXECUTED

The quantities shown in the schedule of quantities are intended to cover the entire new structure indicated in the drawings but the employers reserve the right to execute only a part or the whole or any excess thereof without assigning any reason therefore.

10. OTHER PERSONS ENGAGED BY THE EMPLOYER

The employers reserve the right to execute any part of the work in this contract or any work which is not included in this contract, by other agency or persons and contractor shall allow all reasonable facilities and use of his scaffolding for the execution of such work. The main contractor shall extend all co-operations in this regard.

11. EARNEST MONEY DEPOSIT

The tender will have to deposit an amount of Rs. 15,000/- in the form of bank draft drawn in favor of Indian Bank, Zonal Office, Noida at the time of submission of tender as an earnest money. The employer is not liable to pay any interest on the earnest money. The earnest money of the unsuccessful tenders will be refunded without any interest soon after the decision to award the work is taken or after the expiry of the validity period of the tender.

12. CONTRACTOR TO PROVIDE EVERYTHING NECESSARY:

The contractor shall provide everything necessary for the proper execution of works according to the intent and meaning of the drawings, specifications and Schedule of Quantities taken together whether the same may or may not be particularly shown or described therein, provided that the same can reasonably be inferred there from and if the Contractor finds any discrepancy in the drawings or between the drawings, general conditions, specifications and Schedule of Quantities, he shall immediately refer the same in writing to the employer / Architect, whose decisions shall be final and binding. The contractor shall provide himself for ground and fresh water for carrying out of the works at his own cost. The employer shall on no account be responsible for the expenses incurred by the contractor for hired ground or fresh water obtained from elsewhere.

The rates quoted against individual items will be inclusive of everything necessary to complete the said items of work within the contemplation of the contract, and beyond the unit price no extra payment will be allowed for incidental or contingent work, labor and / or material inclusive of all taxes and duties whatsoever except for specific items. If any, stipulated in the tender documents.

The Contractor shall supply, fix and maintain at his own cost, during the execution of any works, all necessary centering, scaffolding, staging, planking, strutting, hoarding, watching and lighting by bights as well as by day required not only for the proper executions and protection of the said works, but also for the protection of the public and the safety of any adjacent roads, streets, walls, houses, building and all other erections, matters or things. The Contractors shall take down and remove any or all such centering, scaffolding, staging, planking, strutting, etc., as occasion shall require or when ordered so to do and shall fully reinstate and make good all the matters and things disturbed during the execution of the works to the satisfaction of the Employer / Architects.

The contractor shall also provide such temporary roads on the site as may be necessary for the proper performance of the contract and for his own convenience but not otherwise. Upon completion, such roads shall be broken up and leveled where so required by the drawings unless the Employer shall otherwise direct.

The contractor shall at all times, give access to workers engaged by the Employer or any men employed on the buildings, and to provide such parties, sufficient and if required, special scaffolding hoists and ladders and provide them with water and lighting and level or make any holes, groves etc., in any work. Where directed by the employer or as may be required to enable such workmen to lay or fix pipes. Electrical wiring. Special fittings etc. The quoted rates of the tenders shall accordingly include all these above-mentioned contingent works.

13. TIME OF COMPLETION EXTENSION OF THE PROGRESS CHART

1. Time of completion: The entire work is to be completed in all respects within the stipulated period. The work shall deem to be commenced within the Seven days from the date of acceptance letter or date of handing over of site, whichever is earlier. Time is the essence of the contract and shall be strictly observed by the contractor.

The work shall not be considered as complete until the employer / architects have certified in writing that his has been completed and the defect liability period shall commence from the date of such certificates.

2. Extension of time: If in the opinion of the employer / Architects the work be delayed (a) by any exceptionally inclement weather or (b) by reason of instructions from the employer in consequence of proceedings taken or threatened by or disputes, with adjoining or neighboring owner or (c) by the workers, or delay of other contractors or tradesmen engaged or nominated by the employer and not referred to in the specification or (d) by reason of authorized extra or addition or (e) by reason of any combination of workmen or strikes or lock out affecting any of the building trades or (g) from other causes which the employer may consider are beyond the control of the contractor, the employer at the completion of the time allowed for the contract, shall make fair and reasonable extension of time for completion in respect therefore. In the event of the employer failing to give possession of the site upon the day specified above the time completion shall be extended suitably.
3. In case of such strikes or lock-outs, as referred to above, the contractor shall immediately give the employer, written notice thereof. Nevertheless, the contractor shall use his best endeavors all that to prevent delay, and shall do all that may be reasonably required, to the satisfaction of the employer, to proceed with the works and on his doing so that it will be ground of consideration by the employer for an extension of time as above provided. The decision of the employer as to the period to be allowed for an extension of time for completion hereunder (which decision shall be final and binding on the contractor) shall be promulgated at the conclusion of such strike or lock-out and the employer shall then, in the event of an extension

being granted, determined and declare the final completion date. The provision in clause 15 with respect to payment of liquidated damages shall, in such case, be made a construed as if the extended dates fixed by the employer were substituted for and the damage shall be deducted accordingly.

4. **Progress of Work:** During the period of construction the contractor shall maintain proportionate progress on the basis of a program chart submitted by the contractor immediately before commencement of work and agreed to by the employer / architects. Contractor should also include planning for procurement of scarce material well in advance and reflect the same in the program chart so that there is no delay in completion of the project.

14. LIQUIDATED DAMAGES

Should the work not be completed to the satisfaction of the employer / architect within the stipulated period, the contractor shall be bound to pay to the employer a sum calculated as given below by way of liquidated damages and not as penalty during which the wok remains uncompleted or unfurnished after the expiry of the completion date

A	For contracts having time for month or less	2% of the estimated amount shown in Completion 4 the tender per week subject to a ceiling of 10% of the accepted contracted sum
B	For contracts having time for exceeding 6 monthsbut not exceeding 2 years (24 months)	0.5% of the estimated amount shown in Completion the tender per week subject to a ceiling of 7.5%of the accepted contracted sum.
C	For contracts having time for in excess of 2 years	0.25 % of the estimated amount shown in Completion the tender per week subject to a ceiling of 5% of the accepted contracted sum

15. NOTICE AND PATENT OF APPROPRIATE AUTHORITY AND OWNERS

The contractor shall confirm to the provision of any acts of legislature relating to the work and to the regulations and bye-laws of any authorities and / or any water, lighting and other companies, and / or authorities with whose systems the structures were proposed to have connection and shall before making any variations from the drawings or specification that may be associated to so confirm, give the employer / architect written notices for making them and apply for instruction thereon. The employer / architect on receipt of such intimation shall give a decision within the reasonable time.

The contractor shall arrange to give notice required for by the said acts, regulations or bye-laws to be given to any authority and to pay to such authority or to any public officer fees that may be properly chargeable in respect of the work and lodge the receipt with the employer.

The contractor shall indemnify the employer against the claims in respect of patent rights, royalties, damages to the buildings, roads or member of public in course of execution of work and shall defend actions arising from such claims and shall keep the employer saved harmless and indemnified in all respects from such action's costs and expenses.

16. CLEARING SITE AND SETTING OUT WORKS

The site shown on the plan shall be cleared of obstructions, loose stone and materials, rubbish of all kinds. All holes and hollows whether originally existing or produced by removal or loose stone or material shall be carefully filled up with earth well rammed and leveled off as directed at his own cost.

The Contractor shall set out the works and shall be responsible for the true and perfect setting out of the same and for the correctness of the positions, levels, dimensions, and alignment of all parts thereof. If at any time any error shall appear during the progress or on completion of any part of the work, the Contractor shall at his own expenses rectify such error, if called upon to do so the satisfaction of the Architect and the Employer. The contractor shall further set out the works to the alternative positions at the site until one is finally approved and the rates quoted in his tender should include for this and no extra on this account will be entertained.

17. DATUM

The average ground level will be considered as the crown of the nearest road which should be taken as "Datum" which is however subject to final confirmation by the employer / architect. All levels shown in the drawings are to be strictly adhered to.

18. CONTRACTOR IMMEDIATELY TO REMOVE ALL OFFENSES

All soil filth or other material of offensive nature taken out of any trench, sewer, drain, cesspool or other places shall not be deposited on the surface but shall be at once carted away by the contractor to place provided by him.

The contractor shall keep the foundation and works free from water and shall provide and maintain at his own expenses electrically or other power-driven pumps and other plant to the satisfaction of the employer for the purpose until the building is handed over to the employer. The contractor shall arrange for the disposal of the water so accumulated to the satisfaction of the employer and local includes in his rates for the purpose.

19. ACCESS

Any authorized representative of the employer shall at all reasonable times have free access to the works and/or to the workshops, factories or other places where item/items of work are being prepared or manufactured for the contract and also to any place where the materials are lying or from which they are being obtained. The Contractor shall give every facility to the Architect,

Owner and their representative for the inspection and examination and test of the materials and workmanship. Except the representative of employer no person, shall be allowed at any time without permission of the employer.

20. MATERIAL, WORKMANSHIP, SAMPLES, TESTING OF MATERIALS

All the works specified and provided for in the specification or which may be required to be done in order to perform and complete any part thereof shall be executed in the best and most workman like manner with materials of best and approved quality of the respective kinds in accordance with the particular contained in the implied by the specifications and as represented by the drawings or accordance to such other additional particulars and instruction as from time to time be given by the employer / architect during the execution of the work , and to his entire satisfaction.

If required by the employer / architect the contractor shall have to carry out test on materials and workmanship in approved material testing laboratories or as prescribed by the employer / architect at his own cost to prove that the materials etc. under test confirm to the relevant IS standards or as specified in the specifications. The necessary charges for preparation of mound (in case of concrete cube) transporting, testing etc. shall have to be done by the contractor. No extra payment on this account should in any case be entertained.

All the material (except where otherwise described) store and equipment required for the full performance of the work under the contract must be provided through normal channel and must include charge for import duties, sales tax, octroi and other charges and must be the best of their kind available and the contractor/s must be entirely responsible for the proper and efficient carrying out of the work. The work must be done in the best workman like manner. Samples of all materials to be used must be submitted to the employer / architect when so directed by the engineer / architect.

21. REMOVAL OF IMPROPER WORK:

The employer shall, during the progress of the works, have power to order in writing from time to time the removal from the works, within such reasonable time/times, as may be specified in the order, of any materials which in the opinion of the employer /architect are not in accordance, with the specifications or instructions, and the substitution of proper materials and proper re-execution of any work, executed with materials or workmanship, not in accordance with the drawings and specifications or instructions. In case contractor refuse to comply with the orders, the employer shall have the power to employ and pay other agencies to carry out the work and all expenses consequent thereon or incidental thereto as certified by the employer / architect shall be borne by the Contractor, or may be deducted from any money due to or may become due to the Contractor. No certificate which may be given by the architect shall relieve the contractor from his liability in respect of unsound work or bad material.

22. SITE ENGINEER

The term "Site-Engineer" shall mean the person appointed and paid by the Employer superintend the work. The contractor shall afford the Site Engineer every facility and assistance for examining the works and materials and foe checking and measuring work and materials. The Site Engineer shall have no power to revoke, alter, enlarge or relax any requirements of the contractor or to sanction any day work, additions, alterations, deviations or omissions or any extra work whatever, except in so far as such authority may be specially conferred by a written order of the employer.

The Site Engineer shall have power to give notice to the contractor or to his foreman, of non-approval of any work or materials and such work shall be suspended of the use of such materials

shall be discontinued until the decision of the Employer is obtained. The Architects, from time to time, will examine the work. Engineer from the premises Department of the Employer and the Site Engineer. But such examination shall not in any way exonerate the contractor from the obligation to remedy any defects, which may be found to exist at any stage of the work or after the same is complete. Subject to the limitation of this clause the contractor shall take instructions only from the Architects / Employer.

23. CONTRACTOR'S EMPLOYERS

The contractor shall employ technically qualified and competent supervisors for the work who shall be available (by turn) throughout the working hours to receive and comply with instructions of the Employer / Architects. The contractor shall engage at least one experienced Engineer as site-in-charge for execution of the work. The contractor shall employ in connection with the work persons having the appropriate skill or perform their job efficiently.

The contractor shall employ local labors on the work as far as possible. No labor below the age of sixteen years and who is not an Indian National shall be employed on the work.

Any labor supplied by the contractor to be engaged on the work on day-work basis either wholly or partly under the direct order or control of the employer or his representative shall be deemed to be a person employed by the contractor.

The contractor shall comply with the provisions of all labor legislation including the requirements of.

- a) Employer's Liability Act.
- b) Workman's Compensation Act.
- c) Contract Labor (Regulation & Abolition) Act, 1970 and Central Rules 1971
- d) Apprentices Act 1961
- e) Any other Act or enactment relating thereto and rules framed hereunder from time to time.

The contractor shall keep the Employer saved harmless and indemnified against claims if any of the workmen and a costs and expenses as may be incurred by the Employer in connection with any claim that may be made by any workmen.

The contractor shall comply at MS own cost the order of requirement of any Health Officer of the State or any local authority or of the Employer regarding the maintenance of proper environmental sanitation of the area where the contractor's labors are housed or accommodated, for the prevention of small pox. Cholera, plague, typhoid, maintain and keep in good sanitary conditions adequate sanitary accommodation and provide facilities for pure drinking water at all times for the use of men engaged on the works and shall remove and clear away the same in completion of the works. Adequate precautions shall be taken by the contractor to prevent nuisance of and kind on the works or the lands adjoining the same.

The contractor shall arrange to provide first aid treatment to the labors engaged on the works He shall within 24 hours of the occurrence of any accident at or about the site or in connection with execution of the works, report such accident to the Employer and to the competent authority where such report is required by law.

24. DISMISSAL OF WORKMEN:

The contractor shall on the request of the employer immediately dismiss from the works any person employed thereon who may, in the opinion of the employer, is unsuitable or incompetent or who may misconduct himself, and such person shall not again be employed or allowed on the works without the permission of the employer. The employer shall not enter into correspondence for stating the reasons for dismissal of such workmen. Such discharge shall not be the basis of any claim for compensation or damages against the employer or any of their officer or employee.

25. ASSIGNMENT

The whole works included in the contract shall be executed by the contractor and the contractor shall not directly or indirectly transfer, assign or underlet the contract or any part share thereof or interest therein, nor shall take a new partner, without the written consent of the employer and no subletting shall relieve the contractor from the full and entire responsibility of the contract or from active superintendence of the works during their progress.

26. DAMAGE TO PERSONS AND PROPERTY INSURANCE ETC.

The contractor shall be responsible for all injury to persons, property or things and for all structural and decorative damage to property which may arise from operation or neglect or default of himself or of any Sub-Contractor or of any of his or a Sub-Contractor's employees, whether such injury or damage may arise from carelessness, accident or any other cause whatever in any way connected with the carrying out of this contract. This clause shall be held to include, interlace any damage to buildings, whether immediately adjacent or otherwise, any damage to roads, streets, footpaths, bridges, or ways as well as damages caused to the buildings and works forming the subject of this contract by rain, wind or other inclemency of the weather. The Contractor shall indemnify the Employer and hold him harmless in respect of all, and any expenses arising from any such injury or damage to persons or property as aforesaid and also in respect of any claim made in respect of injury or damage under any acts of Governments or otherwise, and also in respect of any award of compensation or damages consequent upon such claim.

The Contractor shall reinstate all damages of every sort mentioned in this clause, so as to deliver up the whole of the Contract works complete and perfect in every respect and so as to make good or otherwise satisfy all claims for damage to the property or third parties.

The contractor shall affect the insurance necessary and indemnify the employer entirely from all responsibility in this respect. The insurance must be placed with a company approved by the employer and must be affected jointly in the names of the contractor and the employer and the policy lodged with the latter. The scope of insurance is to include damage or loss to the contract itself till this is made over in a complete state. Insurance is compulsory and must be affected from initial stage. The contractor shall be responsible for anything, which may be excluded from the Insurance Policies above referred to, and also for all other damages to any property arising out of and incidental to the negligent or defective carrying out of this contract.

The employer shall be at liberty and is hereby empowered to deduct the amount of any damages, compensations, costs charges and expenses arising or occurring from or in respect of any such claims or damages from any sums due or to become due to the Contractor.

27. INSURANCE

Unless otherwise instructed the contractor shall insure the work and keep them insured until the virtual completion of the contract against loss or damage by fire and / or earthquake, flood. The insurance must be placed with a company approved by the employer, in the joint names of the employer and the contractor for such amount and for any further sum if called to do so by the employer, the premium of such further sum being allowed to the contractor as an authorized extra.

The contractor shall deposit the policy and receipts for the premiums with the employer within 10 days from the date of signing the Contract. In default of the Contractor insuring as provided above, the employer on his behalf may so insure and may deduct the premiums paid from any money due or which may become due to the contractor. The Contractor shall as soon as the claim under the policy is settled, or the work reinstated by the In Insurance office, should they elect to do so proceed with all due diligence with the completion of the works in the same manner as though the fire had not occurred and in all respects under the same conditions of contract. The contractor in case, of rebuilding or reinstatement after fire, shall be entitled to such extension of time for completion as the employer may deem fit.

28. ACCOUNTS RECIEPTS AND VOUCHERS

The contractor shall, upon the request of the employer furnish them with invoices, accounts, receipts and other vouchers that they may require in connection with the work under this contract. If the contractor shall use materials less than what he is required under the contract the value of the difference in the quantity of the material he was required to use and that he actually used shall be deducted from his dues. The decision of the employer shall be final and binding on the contractor as to the amount of the material is required to use for any work in this contract.

29. MEASUREMENT

Before taking any measurement of any work the site engineer or a subordinate deputed by him shall give reasonable notice to the contractor. If the contractor fails to attend at the measurement after such notice or fails to countersign or to record the difference within a week from the date of measurement in the manner required by the site engineer then in any such event the measurement taken by the site engineer or by the subordinate deputed by him as the case may be is final and binding on the contractor and the contractor shall have no right to dispute the same.

30. PAYMENTS

The bills of the Contractor's shall be submitted to the Architects which in turn shall duly forward the same certifying the correctness thereof along with all the relevant records to the employer within a week of the receipt of bills and other records from the Architects subject to deduction of applicable taxes, advances, security deposits etc. or such other sums as may be agreed or provided for under the Contract.

All the interim payments shall be regarded as payments by way of advance against the final payments for work actually done and completed , and shall not preclude the requiring of bad , unsound , and imperfect or unskilled work to be removed and taken any and reconstructed , or recreated or be considered as an admission of the performance of the contract , or may part thereof in any respect or the accruing of any claim , nor shall it conclude determine or affect in any way the power of the Employer under these conditions or any of them as to the final settlement and adjustment of the accounts or otherwise or in any other way vary or affect the contract.

Final payment: -The final bill shall be accompanied by a certificate of completion from that employer/ Architect. Payments of final bill shall be made after deduction of retention money as specified in clause 11 of these conditions, which same shall be refunded after the completion of the defect liability period after receiving the employer's / architects' certificates that the contractor has rectified all defect to the satisfaction of the employer / architect. The acceptance of payment of the final bill the contractor would indicate that he will have no further claim in respect of the work executed.

31. VARIATION / DEVIATION

The price of all such additional items/ non tendered items will be worked out on the basis of rates quoted for similar items in the contract wherever existing or on engineering rate analysis based on prevalent fair price of labor, material and other components as required. The tender rates shall hold good for any increase or decrease in the tendered quantities up to variations of 25%. For variation beyond $\pm 25\%$ the rate for the respective items may be reviewed on mutually agreed terms.

32. SUBSTITUTION

Should the contractor desire to substitute any material and workmanship, he / they must obtain the approval of the employer / architect in writing for any such substitution well in advance. Material designated in this specification indefinitely by such terms as "Equal" or other approved etc. specific approval of the employer / architect has been obtained in writing.

33. PREPARATION OF BUILDING WORKS FOR OCCUPATION & USE ON COMPLETION

The whole of the work will be thoroughly inspected by the contractor and deficiencies and defects put right on completion of such inspection the contractor shall inform the Employer that he has completed the work and it is ready for inspection.

On completion the contractor shall clean windows, and doors including oiling, if necessary, of all hardware., inside and outside, stair – case, and every part of the building. He will leave the entire building neat and clean and ready for immediate occupation and total satisfaction of the Bank.

34. CLEARING SITE ON COMPLETION

On completion of the works the contractor shall clear away and remove from the site construction plant, surplus material, rubbish and temporary works of every kind and leave the whole of the site and the works clean and in a workmanlike condition to the satisfaction of the employer / architect.

35. DEFECTED AFTER COMPLETION

The contractor shall make good at his own cost and to the satisfaction of the Employer all defects, shrinkage, settlements or other faults which may appear within 13 months after completion of the work. In default the Employer may employ and pay other persons to amend and make good such damages , losses and expenses consequent thereon or incidental there to shall be made good and borne by the contractor and such damages , loss and expenses shall recoverable from him by the employer or may be deducted by the employer , in lieu of such amending and making good by the contractor deduct from any money due to the contractor a sum equivalent to the cost of amending such work and in the event of the amount retained being insufficient , recover that balance from the contractor from the amount retained under clause No. 12 together with any expenses the Employer any have incurred in connection therewith .

36. CONCEALED WORK

The contractor shall give due notice to the employer / architects whenever any work is to be buried in the earth, concrete or in the bodies of walls or otherwise becoming inaccessible later on, in order that the work may be inspected and correct dimensions taken before such burial, in default whereof the same shall at ht opinion of the employer / architect be either opened up for measurement at the contractor’s expenses or no payment may be made for such materials. Should any dispute or differences arise after the execution of any work as to measurements etc. or other matters which cannot be conveniently tested or checked, the notes of the Employer / Architects shall be a accepted as correct and binding on the contractor.

37. ESCALATION

The rate quoted shall be firm throughout the tenure of the contract (including extension of time, if any, granted) and will not be subject to any fluctuation due to increase in cost of material, labor, sales tax, octroi etc. unless specially provided in these documents.

The price variation clause being adopted by the RBI may be followed, if such a situation arises on a case basis.

38. IDLE LABOUR

Whatever the mesons may be no claim for idle labor, additional establishment cost of hire and labor charges of tools and plants would be entertained under any circumstances.

39. SUSPENSION

If the Contractor, except on account of any legal restraint upon the employer preventing the continuance of the works, or in the opinion of the employer, shall neglect or fail to proceed with due diligence in the performance of his part of the Contract or if he shall more than once make default, the employer shall have the power to give notice in writing to the Contractor requiring that the works be proceeded within a reasonable manner, and with reasonable dispatch, such

notice shall not be unreasonably given and must signify that it purports to be a notice under the provisions of this clause and must specify the acts or defaults on the part of the Contractor upon which it is based.

After such notice shall have been given to the contractor shall not be at liberty to remove the site of works or from any ground continuous thereto any plant and materials to subset from date of such notice being given until the notice shall have been complied with. If the contractor shall fail for 7 (seven) days after such notice has been given to proceed with the works as therein prescribed, the employer may proceed as provided in clause 40 (Termination of contract by employer).

40. TERMINATION OF CONTRACT BY EMPLOYER

If the contractor being a company going in to liquidation whether voluntary or compulsory or being a firm shall be dissolved or being an individual shall be adjudicated insolvent or shall make an assignment or a composition for the benefit of the greater part, in number of amount of his creditors or shall enter in to a deed or arrangement with his creditors, or if the Official Assignee in insolvency, or the receiver of the contractor in insolvency, shall repudiate the contract or if a Receiver of the contractor's firm appointed by the court shall be unable, within the fourteen days after notice to him requiring him to do so, to show to the reasonable satisfaction of the employer that he is able to carry out and fulfill the contractor and if so required by the contractor to give reasonable security therefore, or if the contractor shall suffer execution to be issued, or shall suffer any payment under this contract to be attached by or on behalf of and of the creditors of the contractor, or shall assign, charge or encumber this contract or any payment due or which may become due to the contractor, there under, or shall neglect or fail to observe and perform an or any of the acts matters of things by this contract to be observed and performed by the contractor within three clear days after the notice shall have been given to the contractor in manner hereinafter mentioned requiring the contractor to observe or perform the same or shall use improper materials or workmanship in carrying on to the works, or shall in the opinion of the employer not exercise such due diligence and make such due progress as would enable the work to be completed within due time agreed upon, and shall fail to proceed to the satisfaction of the of the employer after three clear days' notice requiring the contractor so to do shall have been given to the contractor as hereinafter mentioned, or shall abandon the contract then and in any of the said cases, the employer may not withstanding previous waiver determine the contract by notice in writing to the effect as hereinafter mentioned, but without thereby effecting the powers of the employer of the obligations and liabilities of the contractor the whole which shall continue in force as fully as if the contract had not been so determined and as if the works subsequently executed had been executed by or on behalf of the contractor (without thereby creating trust in favor of contractor) further the employer or his agent or servants, may enter upon and take possession of the work and all plants, tools, scaffolding, shed , machinery, steam and other power, utensils and material lying upon premises or the adjoining lands or roads of sell the same as MS own property or may employ the same by mesa of his own servants and workman in carrying on and completing the work or by employing any other contractor or other persons or person to complete the work, the contractor shall not in any way interrupt or do any act matter of thing to prevent or hinder such other contractors or other persons or person employed from completing and finishing or using the material or plants for the works when the works shall be completed, or as soon thereafter as conveniently may be the employer shall give notice in writing to the contractor to remove MS surplus material and plants, and should the contractor fail to do so within 14 days after receipt by him the employer may sell the same by public auction and shall give credit to the contractor for the amount to so released. Any expenses or losses incurred by the employer in getting the works carried out by the other contractor shall be adjusted against the amount payable to the contractor by way of selling his tools or plants or due on account of work carried out by the contractor prior to engaging other contractor or against the security deposit.

41. ARBITRATION

In the event of any dispute or difference whatsoever arising between the parties out of or pertaining to any Clause of this Contract including any question relating to meaning and interpretation of this contract or any alleged breach thereof, except those the decisions whereof have been specifically provided in the Contract, the same shall be settled as far as possible by mutual discussions and consultations between the parties.

In case of failure to resolve the difference/dispute in the above manner, the same shall be referred to the sole arbitration of any person appointed by mutual consultation of employer and contractor, who shall be presently unconnected with the organization for which the work is executed.

The Arbitrator shall give a separate award in respect of each dispute or difference referred to him.

The Arbitrator shall decide each dispute in accordance with the terms of the contract and give a reasoned award.

The venue of the Arbitrator shall be such place as may be fixed by the arbitrator in the sole discretion.

The fees, if any of the arbitrators shall if required to be paid before the award is made and publishing, be paid half by each of the parties. The cost of the reference and of the award including the fees if any, of the arbitrator who may direct to and by whom and in what manner, such cost or any part thereof shall be paid and may fix or settle and amount of costs to be so paid.

The award of the Arbitrator shall be final and binding on both the parties.

Subject to aforesaid the provision of the arbitration act 1940 or any statutory modification or re-enactment thereof and the rules made there under, and for the time being in force, shall apply to the arbitrator proceeding under this clause.

The employer and the contractor hereby also agree that arbitration under clause shall be a condition precedent to any right and action under the contract with regard to the matters hereby expressly agreed to be so referred to arbitration.

CONDITIONS FOR ELECTRICAL WORK

NOTE: -

These preambles apply to all the sections of schedule of quantities and tendered rates shall take into account all the provisions additions to various pro visioning their parts of the tendered documents.

1. The quantities given in schedule are provisional. The contractor will be paid for the actual quantity of work executed at site at the rates quoted in his tender. The owner reserves the right to increases or decreases any of the quantities or to totally omit any item of work. The variation due to the above shall be limited to 5% of the total contract amount. Any claim by the contractor in these accounts will not be been retrained.

2. All the items of work given in this schedule of quantities shall be executed strictly in accordance with the Indian Electricity Act. The Indian electricity rules and requirements of the Electric supply authority read in conjunction with the relevant drawings, specifications and the appropriate Indian Standards.

3. All measurements shall be taken in accordance with the Indian Standard Electrical Installation in buildings method of measurement of IS unless otherwise specified.

4. The contractor shall visit the site of work and shall satisfy himself if as to conditions under which the work is to be performed. No extra claim consequence of ignorance or on grounds of insufficient description will be allowed at later date.

5. No alteration whatsoever is to be made to the text or quantities of this schedule of quantities sun less alteration is authorized in writing by the owner. Any such alterations, notes or additions shall, unless authorized in writing the disregarded when tender document sere considered.

In the event of error occurring to the amount column of the schedule, as a result of wrong extension of until rate and quantity, the until rate quoted by the tender shall be regarded as firm and the extensions shall be amended on the basis of rates.

Any error in description or in quantity or mission of items from the contract

Schedule shall not vitiate this contract but shall be corrected and deemed to be variation required by the owner.

GENERAL CONDITIONS:

The specification generally applicable to this works shall be as per C.P.W.D. Specifications for Electrical work at Delhi except as otherwise specified in the description of items given in the schedule of quantities or in the General and Technical specifications the requirement of these specifications will be fulfilled by the Contractor within the Tendered rates and without extra charge. The item rates quoted shall be deemed to have taken this specification into account.

1. The Electrical work will be carried out generally in accordance with the General Specification 1972 with amendments up-to-date for Electrical work in Central Government buildings while complying in all respects with the requirements of the latest Indian Electricity Rules in force for the time being.

2. The Electrical shall be carried out simultaneously with building work and will be continued until it is completed satisfactorily along with the completion of essential portions of building work.

If any Minor alterations are found necessary, the contractor will do the same within the tendered rates.

The work will be carried out in the best workman like manner and any defect in the work or changes in the design etc. If pointed out shall be carried out by the contractor within the tendered rates.

The contractor shall employ adequate labor to complete the work within the stipulated time and make his own arrangements for housing labor and storage of materials etc. A whole time Electrical Supervisor/Engineer shall be employed by the contractor who will remain at site of work to receive orders or other instructions from the Architects/Engineer-in-charge/consultant.

Any material supplied by the Employers, if damaged in any way during cartage or execution of work or otherwise, shall be made good by the contractor at his own cost.

During, the progress of work, portions of the building may be occupied and put to use by the owner but contractor will remain fully responsible for maintenance of the Electrical Installations till the entire work covered by this contract is satisfactorily completed by the Architects/Engineer-in-charge/consultant.

8. CONTRACTOR TO OBTAIN INFORMATION BY HIMSELF

The contractor shall obtain for himself on his own responsibility and at his own expenses all the information which may be necessary for the purpose of tendering and for entering into contract, and must examine and study the specifications, drawings the design of electrical installation, inspect the site, the building plans etc. If the drawings are supplied to the contractor for tender purposes, the same must be returned in good condition with the tender. The contractor shall also not withhold information given to him, make local and independent Enquiries.

9. TENDER RATES

All Tender rates will include for the cost of materials, erection connections, labor, supervision, tools, plant, transport all taxes contingencies, breakage, wastage, sundries, scaffolding, maintenance of install action for one year etc. i.e. they should debtor an item complete in all respect.

10.APPROVALS

The contractor, while executing the work, shall conform to the provision of any Government Act relating to the work and to the regulations and Byelaws of the local authorities, and of the Company to whose system of supply the installation is proposed to be connected. The contractor shall give all notices, required by the Acts, Regulation of Bylaws. He will also undertake to provide test certificate and drawings as required and will make necessary arrangement stop procure electricity supply without any extra charge. The contractor shall also obtain all approvals for the item of work done under this contract from the appropriate authorities. All inspection fees or submission fees paid by the contractor will be reimbursed by the owner against valid official receipts. Contractor shall possess valid electrical Contractor's License issued by the inspectorate of the Local Government, 'A' Class license category holders.

11.SAMPLES:

Samples of materials and fabrication drawings will be submitted by the contractor according to the schedule/specifications. Any deviation from the schedule/specification will have the written consent of the consultant/Architects. No approval given by the Consultants /Architect to any samples or drawings submitted by the Contractor shall in any way exonerate the contractor from his liability to carry out the work the accordance with the terms of contract.

12. DRAWINGS:

A. WORKING DRAWINGS

The contractor will submit 4(four) sets of working drawings indicating detailed layouts for approval and proceed with work there-after. All fabrication drawings and other literature will also be submitted in advance for approval.

B. COMPLETIONS DRAWINGS

The contractor shall submit one complete set of Original Tracing and further two copies of layout drawings to the Consultants/Architects after completion of the work. These complete drawings shall give the following information:

I. Runs of conduits, Diameter of conduit, number of wires contained in each conduit and size of wire for point wiring, mains, sub mains.

II. Location fall Distribution Boards, Main Switches, Junction and outlet boxes.

III. Complete Schematic Diagram of the installation. Cables, dummy pipes, earthing and communication systems and all other services covered under this contract.

IV. The Drawings will be submitted in 4 (four) different sets as below: -

SET NO:1:

V. Lighting layout giving details of the entire lighting system.

SET NO:2: Power layout giving details of the entire power system.

SETNO: 3: Communication layout, mains, sub mains, Lighting Protection, earthing system and any other detail not covered in earlier drawings.

SETNO: 4: Schematic diagram.

No completion certificate will be issued until the completion drawings in the above mentioned form are submitted. The drawings will be prepared and submitted by the contractor without extra charge Rs.10,000/- may be kept for non-completion of these.

13. PROGRESS AND TIME OF COMPLETION

a. The work will commence immediately after the contractor receives instructions to proceed.

b. The contractor will work in cooperation with the building contractor and other contractors and shall arrange to place his conduits in the masonry and concrete work as the building or other work proceeds. Any hold up of the building or other work because of delay in laying of conduits or otherwise, shall be the responsibility of the Electrical Contractor and will make him liable for damages if any, by the Employers.

c. The contractor shall in consultation with the Consultants/Architects draw up a time schedule on commencement of the work. This time schedule will be strictly adhered to.

SPECIFICATIONS

1. INTERNAL WIRING

System of wiring

The system of wiring shall consist of single core PVC insulated standard copper conductor in PVC conduits concealed or exposed as called fronted drawings.

General

Prior to laying and fixing of conduits, the Contractor shall carefully examine the drawings indicating the layout of conduits, satisfy himself about the sufficiency of number and size of conduits, location of junction boxes, sizes and location of switch boxes and other relevant details. Any discrepancy found in the drawings shall be brought to the notice of the Employer/ its representative. Any modifications suggested by the Contractor shall be got approved by the Architect before the actual laying of conduits is commenced.

Materials

PVC Conduits: PVC conduits shall be of min 2mm wall thickness and ISI marked to heavy duty.

Connections

All joints shall be fully water tight and sealed by applying cementing jointing compound as per manufacturer's recommendation. Junction boxes and running joints shall be provided at suitable places to allow for subsequent extensions, if any, without undue dismantling of conduit system. As far as possible, diagonal run of conduits shall be avoided. Conduit system shall be erect and straights far as possible. Separate conduits shall be run for 15amps-power outlet wiring. The Joints in conduit shall be free of burrs to avoid damage to installation of conductors while pulling them through the conduit.

Bends in Conduit

Where necessary, bends or diversion maybe achieved by means of bends and/or circular inspection boxes with adequate and suitable inlet and outlet connections. In case of recessed system each junction box shall be provided with a cover properly secured and flush with the finish wall surface, so that the conductors inside the conduit are easily accessible. No bend shall have radius less than 2½ times the outside diameter of the conduit.

Fixing Conduits

Conduits and junction boxes shall be kept in position while the walls, slabs and floor are under construction and proper hold fasts shall be provided. Conduits shall be so arranged as to facilitate easy drawing of wire through them. Adequate junction boxes of approved quality and size shall be provided. Where conduits Cross expansion joints in the building, adequate expansion fittings or other approved devices shall be used to take care of any relative movement. All conduits shall be installed so as to avoid steam and hot water pipes. Conduit stubs in floor slabs shall be kept as short as possible above finished floor level in order to avoid any damage to them. After the conduits, junction boxes, outlet boxes and switch boxes are installed in position, their outlet shall be properly plugged or covered so that water, mortar, insects or any other foreign matter does not enter into the conduit System. Where called for, surface conduits shall be fixed by means of spacer bar saddle sat intervals not more than 1000mm and 100 mm from both sides of fitting or accessories. The saddles shall be 3mm x19mm galvanized mild steel flat, properly treated, securely fixed to support by means of raw bolts and brass machine screws. Conduit in chases shall be avoided. Where nevoid able, conduit shall be fixed by means of Staples not more than 600mm apart and the chases filled with cement mortar 1:6 Cutting of horizontal chassis prohibited. All socket reconnection shall be made fully water tight by the use to suggested by manufacturer PVC Conduits.

Switch outlets & Junction boxes

All outlets for switches, sockets and other receptacles shall be equipped with rust proof outlet boxes of sheet steel fabricated from 16SWG sheet as called for having smooth external and internal surface to true finish. Where called for, outlet boxes for receiving's switches and fan regulators shall be fabricated to approved sizes and covered with 3/16th inch thick decorative laminate sheet. Outlets exposed to the weather shall be fully weather tight, complete with rubber gasket covers. Outlets where used shall be painted with two coats of bituminous paint for their fixed imposition, outlet boxes fixed in concrete shall have a minimum depth of 75mm and the wall thickness of the box and spouts shall not be less than 2mm.

Inspection Boxes

Rust proof boxes of cast iron and required size, having smooth external and internal finish, shall be provided to permit periodical inspection and to facilitate removal and replacement of wires when required. Inspection boxes shall be mounted on walls/ ceiling finished surface and shall be provided with 3/16th inch thick decorative laminate sheet cover to the box with brass screws. Adequate ventilation holes shall be provided in the inspection box covers.

Telephone system

Conduit, junction boxes, draws boxes, outlet boxes and covers to boxes for telephone system shall be as described under relevant clauses elsewhere in these specifications. The conduit for tele-phone wiring shall be of specified size and shall terminate at outlets as indicated on the drawings. All telephone system conduits shall have '14' SWG galvanized steel pull wires installed.

Conductors

All PVC insulated copper conductor wires shall conform in all respects to Indian Standards.

Bunching of wires

Wires carrying current shall be so bunched in the conduit that the outgoing and return cables are drawn in the same conduit. Cables originating from two different phases shall not be run in the same conduit.

Drawing Conductor

The drawing and jointing of copper conductor wires and cables shall be executed with due regard to the following precaution: While drawing insulated wires in to the conduits, care shall be taken to avoid scratches and kinks, which cause breakage of conductors. There shall be no sharp bends. Insulation shall be shaved off like sharpening of a pencil and it shall not be removed by cutting its quire of wiring. Strands of wires shall not be cut for connecting terminals. The terminals shall have sufficient cross-sectional area to take all strands and shall be thinned. The connecting brass screws shall have flat ends. All looped joints shall be connected through terminal blocks / connectors. The pressure applied to tighten terminal screws shall be just adequate, neither too much nor too less. Conductor having nominal cross-sectional area exceeding 4 Sq.mm shall always be provided with cable sockets. At all bolted terminals, brass flat washers of large area and approved steel spring washers shall be used. Brass nuts and bolts shall be used for all connections. Only certified wiremen and cable jointers shall be employed to do jointing work. All wires and cables shall bear the manufacturer's label and shall be brought to site in new and original packaging. For all internal wiring, PVC insulated wires of 250/440 volts grade shall be used. The sub-circuit wiring for points shall be carried out in looping in system and no joints shall be made.

SWITCHES, RECEPTACLES & FIXTURES

Switches

All 5/15amp switches shall be piano type switches 220 V A.C. All switches shall be fixed inside this witch boxes on the cover plates with Brass machine screws and nuts leaving ample space at the back and sides for accommodating wires. Flush mounted fan regulators shall be fixed inside this witch boxes over the cover plate with brass machine screws and nuts. The switch controlling the light point or fan shall be connected on the phase wire of the circuit. Switches shall be located at 1200mm above floor level unless otherwise indicated. Cover Plates: All switch receptacles and telephone system outlets in the walls shall be provided with white urea powder pressed cover plate of standard configuration of Switch remanufacturer. The cover plates shall be secured to the box with countersunk brass screws.

Wall socket outlet

All 5-amp 3pin socket outlets were called for shall be switches and 3 pin type. All 15-amp 3 pin wall socket outlets were called for shall be switched. The sockets shall be erected approximately 150 mm above floor level (to the bottom of the box), unless otherwise specified. The switch controlling the point outlets and socket outlets shall be on the phase wire of the circuit. The earth terminal of the socket shall be connected to the earth terminal provided inside the box by means of 2.5sq. mm insulated copper wire. No joints are allowed in the length of the conductors. If the use of joint connections is unavoidable due to any specific reasons, prior permission in writing shall be obtained from the employer/ its representative/ Engineer in charge before the use of such connections. No wire shall be drawn into any conduit, until all work, of any nature that may cause injury to the wire, is completed. Care shall be taken in pulling the wires so that no damage occurs to the installation of the wire. Before the wires are drawn into the conduits, the conduits shall be thoroughly cleaned of moisture, dust, dirt or any other obstruction by forcing compressed air through the conduit. The minimum size of PVC insulated copper conductor wires for all sub circuit shall be as follows: Wiring for lights, exhaust fan sand ceiling fan points shall be 1.5sq.mm. The two 15-amp power out let's shall be grouped be 1.5 sq.mm. The two 15-amp power outlets shall be grouped in one circuit were called for, wiring for the first power outlet shall be carried out with 4 sq.mm. PVC insulated copper conductor wires. Wiring for the second power outlet shall be carried out with 4 sq.mm. All power outlets shall be provided with 2.5sq.mm insulated copper earth wires.

Color code conductors

Color code shall be maintained for the entire wiring installation: Red, Yellow, Blue for the three phases, Black for neutral, Green for earth.

Ceiling fans

All ceiling fans shall be provided with suspension arrangements in the concrete slab / roof numbers. It is the duty of the contractor to make those provision sat the appropriate test age of construction. The fan hook boxes shall be fabricated from 16 SWG sheet steel in hexagonal shape and provided with 12mm dia. MS rod bent to shape. Exhaust fans shall be fixed at location shown on the drawings. They shall be wired to a plug socket and at a convenient location near the fans. All switch and outlet boxes fan and light fittings shall be bonded to earth through copper wire properly screwed into the body to make an effective contact.

3.CABLES

General

MV cables shall be supplied, inspected, laid, tested and commissioned in accordance with drawings, specifications, relevant Indian Standard. Specifications and cable manufacturer's instructions. The cable

shall be delivered at site on original drums with manufacturer's name clearly written on the drums. The recommendation of the cable manufacture with regard to jointing and sealing shall be strictly followed:

Materials

The MV cables shall be PVC insulated Aluminum conductor armored cable conforming to IS: 1554 laid in trenches, ducts and underground as shown on drawings.

Inspection

All cables shall be inspected upon receipt at site and checked for damage during transit.

Cable termination

Cable terminations shall be done in terminal cable box using cable glands. All pipe sleeves shall be sealed with sealing compound.

Bonding of cables

Where a cable enters any piece of apparatus it shall be connected to the casing by means of an approved type of armored clamp and gland. The clamps must grip the armoring firmly to the gland or casing, so that no undue stress is passed on to the cable conductors due to vibrations. The gland or cone shall be capable of effecting a good electrical bond between both the armoring and the casing.

Laying cables

Cables shall be laid by skilled and experienced work men using adequate rollers to minimize stretching of the cables. The cable drums shall be placed on jacks before unwinding the cable, Great care shall be exercised in laying cables to avoid forming kinks, the drums shall be unrolled and cables run over wood rollers in trenches at intervals not exceeding 2 meters. Cables shall be laid at a depth of 0.75 meters below ground level.

A cushion of sands, not less than 80mm shall be provided both above and below the cable and joint boxes and other accessories. Cables shall not be laid in the same trench or alongside of a water main. The cables shall be laid first in excavated trench and a layer of 80mm sand shall be lifted and placed over the sand bed. The second layer of 80 mm sand shall then be spread over the cable. The relative position of the cables, laid in the same trench shall be preserved and the cables shall not cross each other as far as possible. At all changes in directions in horizontal and vertical planes, the cable shall be bent smooth with a radius of bend not less than 12 times the diameter of cable. Minimum 3 meters long loop shall be provided at both sides of every straight joint and 5 meters at each end of cable. Distinguishing marks shall be made on the cable ends for identification. Insulation tapes of appropriate voltage and in red, yellow and blue colors shall be wrapped just below the sockets for phase identification.

Protection of cables

The cables shall be protected by bricks on the top layer of sand for the full length of underground cable. Where more than one cable is running in the same trench, the bricks shall cover all the cables and shall project minimum of approximately 80 mm on either side of the cables.

Cables under road crossing and any other places subject to heavy traffic shall be protected by running the cables through a pipe of suitable size. The depth of the pipe shall be 1 meter below the finished road level.

Excavation & Back Filling

All excavation and back fill including timbering, shoring and pumping required for the installation of the cables shall be carried out by the Contractor in accordance with the drawings and requirements laid down

elsewhere. Trenches shall be dug true to line and grades. Back fill for trenches shall be filled in layers not exceeding 150 mm. Each layer shall be properly rammed and consolidated before laying the next layer. The Contractor shall restore all surfaces, roadways, sidewalks, curbs, walks or other works cut excavation to their original conditions, satisfactory to the employer/its representative, including disposal of surface soil as directed.

Testing of cables

Prior to laying cables, the following tests shall be carried out: Insulation test between phases, phase and earth for each length of cable before and after jointing.

On completion of cable laying work, the following test shall be conducted in the presence of the employer/its representative.

- a. Insulation Resistance Test (Sectional and overall)
- b. Continuity Resistance Test
- c. Earthing Test.

All tests shall be carried out in accordance with relevant Indian Standard Code of Practice and Indian.

Electricity Rules. The Contractor shall provide necessary instruments, equipment and labour for conducting the above test and shall bear all expenses in connection with such tests. All tests shall be carried out in the presence of the employer/its representative.

Markers & Warning Plates

Approved CL cable markers shall be provided along the route of the cables at every 30 meters distance and at both ends of road crossing indicating "MV Cable" Special CL markers shall be provided data all buried cable joints indicating "ELECTRICAL CABLE JOINT"

5 DISTRIBUTIONBOARDS

The Distribution Panel and Distribution boards shall be suitable for operation on 3phase/single-phase/singlePhase415/ 230volts.50cyclesneutral grounded at

Trans former and short circuit level not less than 9 ka at 415volts.

The distribution panel/Board shall comply with the latest edition of rail event Indian Standard sand Indian Electricity Rules and Regulations.

Construction

The Distribution panels/boards shall be CRCA sheet steel cubical, indoor, dead front, floor mounting/wall mounting type. The distribution board shall be totally enclosed, completely dust and vermin proof. Gaskets between all adjacent units and beneath all cover shall be used to render the joint duster proof. Distribution board shall be preferably arranged in multitier,

Bus Bar Connections

Rectangular cross section suitable for full load current for MCB'S shall be provided on the phase of live conductors of each circuit, and a neutral bar for earthed neutral. The individual banks of MCB'S shall be detachable. Phase separationbarriersof3mmthick Bakelite sheet shall be provided between. There shall be ample space behind the fittings to accommodate all the wiring. All the internal wiring of distribution boards shall be concealed behind 3mm thick Bakelite sheet. All the distribution boards shall be completely factory wired, read for connections. All the terminals shall have adequate current rating and size to suit individual feeder requirements. Each circuit shall be clearly numbered from left to right to correspond with the wiring diagram. All the switches and circuits shall be distinctly marked with a small description of the service installed.

Switch Fuse

The switch fuse units shall be 3 pole double break type suitable for load duty quick make and break action. Separate neutral link shall be provided in the switch. All switch fuse units shall be provided with hinged doors duly interlocked with operating mechanism, so as to prevent opening of the door when the switch is in "ON" position and also to prevent closing of the switch when the door is not properly secured. All contacts shall be silver plated

and all live parts shall be shrouded. High rupturing capacity (HRC) fuse links shall be provided with switch fuse unit sand shall be in accordance with IS:2208 and having rupturing capacity not less than 31 MVA at 415 volts. HRC fuse links shall be provided with visible indicators to show that they have operated.

Earthing

Copper earth bars of 25mmx3mm shall be provided for the distribution panel for the full length of the panel and connected to the frame work. Provisions shall be made for

Connection from this earth bar to the main earthing on both sides of the distribution panel.

Painting

All sheet steel shall undergo a process of degreasing, pickling in acid, cold rinsing, and phosphate passivating and then sprayed with a high corrosive resistant primer. The primer shall be baked in an oven. The finishing treatment shall be by application of two coats of synthetic enamel paint of approved color and staved.

Labels

Engraved PVC labels shall be provided on all incoming and outgoing feeder switches. Circuit diagram showing the arrangement of the circuit inside the distribution board shall be pasted on inside of the panel door and covered with transparent laminated plastic sheet. All the distribution boards shall be subject to tests specified in relevant Indian Standard and test certificates shall be furnished.

5. EARTHING

All the non-current carrying metal parts of electrical installation shall be earthed properly. All metal conduits, trucking, cable sheaths, switchgear, distribution fuse boards, lighting fittings and all other parts made of metal of specified earthing conductor shall be connected to an efficient earth electrode. All earthing will be in conformity with the relevant provision of rules 33 and 61 of the Indian Electricity Rules 1956, and Indian Standard Specifications IS:3043.

Earthing Conductors

Every earthing conductor shall be of bare G.I./Copper/insulated copper as called for on drawings/specified in bills of quantities and shall be protected against mechanical injury or corrosion.

Sizing of Earthing Conductors

The cross-sectional area of earthing conductor shall be as called for on the drawing.

Construction of Earthing conductors

Main earthing conductors shall be taken from the earth connectors at the main switch boards to an earth electrode with which the connection is to be made. Sub - main earthing conductors shall run from the main switch board to the sub-distribution boards. Circuit earthing conductors shall run from the exposed metal of equipment and shall be connected to any point on the earthing conductors, or its distribution board.

Stations Pipe Earthing:

Earthing electrode shall consist of a C.I. pipe (12 mm wall thickness) of 100 mm dia and 3.7 meters long. The electrode shall be buried vertically in the ground as far as practicable below permanent moisture level with its top not less than 200 mm below ground level. The electrode shall be in one piece and no joints shall be allowed in the electrode. Wherever possible earth electrodes shall not be located in proximity to a metal fence. It shall be kept clear of the building foundations and in no case shall be nearer than 2 meters from the outer face of the wall. The pipe earth electrode shall be kept vertically and surrounded with 150 mm thick layer of charcoal dust and salt mixture up to height of 2.5 meters from the bottom. At the top of the electrode funnel with mesh shall be connected to the electrode, just below the funnel, with proper terminal lugs and check nut. The funnel over the C.I. pipe and earth connection shall be housed in a masonry chamber, approximately 300 mm long, 300 mm deep. The masonry chamber shall be provided with a cast iron cover resting over a CI frame embedded in masonry.

Earthing Connections

All metal clad switches and other equipment carrying single-phase current shall be connected to earth by a single connection. All metal clad switches carrying medium voltage shall be connected to earth by two separate and distinct connections. The earthing conductors inside the building where overexposed shall be properly protected from mechanical injury by running the same in G.I. pipe of adequate size. The earthing conductor shall be painted to protect it against corrosion.

Earthing conductor outside the building shall be laid 600 mm below the finished ground level. The overlapping lugs in joints shall be reverted. Lugs of adequate capacity and size shall be used for all termination of conductor wires above 6sqw.mm size. Lugs shall be bolted to the equipment body to bear the load after the metal body is cleaned of paint and other oily substance.

Resistance to Earth

Their Resistance of each earth system shall not exceed 1.0 ohm.

6. Testing

General

After the completion of the work then in stall action shall be subject to following tests:

1. Wiring continuity test
2. Insulation continuity test
3. Earth continuity test
4. Earth Resistivity test

Besides the above tests any other tests specified by the local authority shall also be carried out. All tested and calibrated instruments for testing, labour and materials and incidentals necessary to conduct the above tests shall be provided by the contract at its own cost.

Testing of Wiring

The entire wiring systems shall be tested for continuity of circuits, and earthing after wiring is completed and be foreigner gazing by the Contractor in the presence of the Architects.

Insulation Resistance Test

The insulation resistance shall be measured by applying between earth and the whole system of conductors or any section thereof, with all fuses in place and all switches closed and except in concentric wiring wall amp position of both poles of the installation otherwise electrically connected together, a direct current pressure of not less than twice the working pressure provided that it does not exceed 660 volts for medium voltage circuits. Where the supply is derived from AC-three-phase system, the neutral pole of which is connected to earth, either direct or through added resistance, pressure shall be deemed to be that which is maintained between the phase conductor and the neutral. The insulation resistance measured as above shall not be less than be carried out after removing all metallic connections between the two poles of the installation and in these circumstances the insulation resistance between conductors of installation shall not be less than specified above. The insulation resistance between the case of frame work of housing and power appliance and all live parts of earth appliance shall not be less than specified in the relevant Indian Standard specification.

Earth Continuity Test

The earth continuity conductor metallic envelopes of cables shall be tested, for electric continuity and the electrical resistance of the same along with the earthing lead but excluding any added resistance or earth leakage. Circuit break measured from the connection with the earth electrode to any point in the earth continuity conductor in the completed installation shall not exceed one ohm.

Testing of Polarity of Non-linked single pole switches

In a two-wire installation a test shall be made to verify that all non-lined single pole switches have been fitted in the same conductor throughout and such conductor shall be labeled or marked for connections to an outer or phase conductor or to the non -earthed conductor of the supply. In the three or four wire installation at rest shall be made to verify that every non-linked single pole switch is fitted in a conductor to one of the outer or phase conductor of the supply.

The entire installation shall be subject to the final acceptance of the employer as well as the local authorities.

Earth Resistivity Test.

Earth resistivity test shall be carried out in accordance with Indian Standard code of practice for earthing IS: 3043. All tests shall be carried out in the presence of employer's representative.

I.S. STANDARD

In general, the materials, equipment and workman ship shall conform to the following Indian Standard, unless otherwise called for: -

1.PVC Insulated (Heavy Duty) cables for working voltage up to & including 1100v (Revised).	:I.S.	1554	-1976	PT	1
2.PVC Insulated Cables (for voltage upto1000v)	:I.S.	694	-1977		
3.Rigid Steel Conduits for Electrical Wiring (Second Revision)	:I.S.	9537	-1972		
4.Accessoriesforrigidsteel conduits for electrical wiring	:I.S.	3837	-1976		
5.Boxes for then closures of Electrical accessories.	: I.S.	5133	-1969		
6. 3 Pin plug & socket outlets	:I.S.	1293	-1967		
7. Adhesive insulating tapes for Electrical Lighting fitting	: I.S.	2448	-1968	II	
8.General safety requirements for Electrical Lighting Fittings.	:I.S.	1913-	1969		
9. Electric Ceiling Fan sand regulators.	:I.S.	347	-1966		
10.Propellor type AC ventilating fan	:I.S.	2312	-1967		
11.Code of practice for earthing	: I.S.	3043	-1987		
12.Code of practice for safety of building (General)Electrical installation	:I.S.	1646	-1961		
13. Air boreal switches & fuses combination unitsforvoltagenotexceeding1000VACor1200 VDC.	:I.S.	1904		-1976	
14.HRCCartridgefuselinkupto650V	:I.S.	9224		-1979	
15.Protection of Building and allied structure against lighting.	:I.S.	2309	-1969		
16.Fittings for rigid steel conduits for Electrical wiring.	:I.S.	2667-		1976	
17. Heavy duty air brake switch & composite uni to fair break switches & fuses for voltage not exceeding1000V	: I.S.	4064	-	1978	

**18. General requirements for switch gear & control-
Gear for voltage not exceeding 1000V : I.S. 4237 - 1982**

19. Switch socket outlet : I.S. 4615 - 1968

**20 MCCB, MCB, RCCB : AS PER I.S.
SPECIFICATIONS**

**21 CONDUITS : AS PER I.S.
SPECIFICATIONS**

AC TECHNICAL SPECIFICATIONS

1 SCOPE

The scope of this Section comprises the installation, testing and commissioning of the air-conditioning machines conforming to these specifications and in accordance with the requirements given in Schedule of Equipment's.

2. AIR CONDITIONING UNITS

HI-WALL UNITS TO BE INSTALLED & their individual Remote controls to be installed on the location approved by the Architect / Consultant.

3. INSTALLATION

- 3.1 Condenser and Fans shall be enclosed in powder coated housing. Refrigerant piping shall be of IMPORTED Copper tube conforming to JIS-H3300 of thickness 0.61 mm for sizes 1/4" to 3/8" and 0.71 mm for sizes 1/2" , 5/8" & 6/8" suitable for specified test pressures. The Installation charges should be inclusive five rmt. of refrigerant piping & interconnected wiring for each unit, which shall be enclosed in the flexible sleeve/ PVC conduit pipes, as required by the consultant. The contractor shall supply foundation bolts, nuts, washers, leveling screws, mounting frame base plate, vibration isolation pad etc. as required by the consultant, and it shall be the responsibility of the contractor to see that all the above items are properly and securely placed in the position on the foundation and get it verified by the consultant.
- 3.2 The contractor shall supply the required charges of refrigerant, lubricants and other consumables for testing and commissioning of the equipment.
- 3.3 The unit shall be properly leveled before grouting the foundation bolts.
- 3.4 All the equipment's shall be thoroughly tested and checked for leaks. The refrigeration system shall be vacuumized to within 5 mm Hg. absolute and maintain for four hours. At the end of this period, the pumps shall be stopped and vacuum maintained for 24 hours without exceeding a vacuum drop of 1 mm Hg. absolute. The contractor shall certify that the vacuum was maintained as specified above.
- 3.5 All safety controls, low and high refrigerant pipe controls, LP-HP, internal OLP, Single phase preventer, auto-correction of phase misbalancing & phase reversal, starter overload trips shall be provided & suitably set and a record of all these settings shall be furnished to the consultant.
- ### 4. TESTING
- 4.1 Unit capacity in tons of refrigeration shall be computed as required by the consultant Burman Et. Al., Computed results shall tally with the figures furnished by the tenders and as inspected during the pre dispatch inspection by the consultant at Manufacturer's factory.
- 4.2 All the instruments, services etc. needed for the test required for the computation of the capacities and the power consumption shall be furnished by the contractor.

AC - MODES OF MEASUREMENTS

1 PIPING WORK

- a) The lengths of piping shall be measured as per distance between INDOOR & OUTDOOR UNITS and accessories and fittings shall be measured along its center line in meters and no separate measurement for bends, elbows, tees etc. shall be made. As such fittings / accessories shall be treated as normal piping work.
- b) All kind of supports, hangers etc. shall form part of the piping work and no extra measurements shall be made.

SECTION – 4.3

SERVICES TO BE PROVIDED BY CUSTOMER

- a) Main incoming power supply to Main Panel / units, along with suitable size Switch fuse unit.
- b) Any kind of exposed roof insulation work. Provision of venetian blinds.

**LIST OF APPROVED AND NOMINATED MANUFACTURERS /
SUPPLIERS OF INTERIOR MATERIALS FOR INDIAN BANK AT MODI
NAGAR STATION ROAD BRANCH , GHAZIABAD.**

S.NO.	MATERIALS	APPROVED BRANDS
1	False Ceiling, Cornices and Channel (GI Section)	India Gypsum , Boral, St. Gobain
2	Grid Ceiling	Armstrong/Gypro/luxelon
3	Wood Frame work: All wood must be well seasoned, free from knots, other defects.	Meranti (seasoned) with two coats of wood preservative
4	Aluminium frame work	Jindal/Indal/Hindalco
5	Wood skirting /mouldings, Lipping /beading	Steam beech/ Mahogany/ Teak wood
6	Commercial Ply wood/EDHMR (6mm,8mm,12mm,19mm)	Archid/Green ply/Century
7	Laminate	Century/Merino/Greenlam/Aica
8	Veneer	Archid/Century/Greenlam
9	Wood Preservative	STP- Pentaphene pale / Termination Tor(Pidilite)
10	Adhesive	Fevicol SH (Pidilite) / Araldite/SR- 998/Century – SH
11	Door Closer	Dorset/Hettich/Hafele
12	Floor Spring	Dorma/ Dorset/Hettich
13	Door Lock	Dorset/Golden/ Ozone
14	Drawer Lock	Dorset/Golden/Hettich
15	Hardware	GKW/Everite
16	Hinges	Hettich/Ebco/Hefele
17	Screws	GKW/ Nettle fold
18	Carpet	Interface/ Shaw
19	Vertical/Roller Blinds	MAC/Vista
20	Sun Control Film	3M
21	Soft Board / Display Board	Jolly board/Western India Plywood
22	Paints	Berger/ Asian/ Nerolac
23	Texture paint	Spectrum/ Oikos
24	Ceramic Tiles	Nitco/Orient bell/H.R.Johnson
25	Vitrified tiles	Nitco/Orient bell/ H.R.Johnson
26	Glass & Mirror	Modi Guard/ Saint gobain/Ashai
27	Handle	Dorset/Hefele/ Hettich
28	MDF Boards	Greenpanel max/Century/Action
29	Wooden flooring	Green panel max/Pergo/Armstrong
30	PVC flooring	Armstrong/ Krishna vinyl

31	Sanitary fittings	Toto/ Roca/ Kohler/ Grohe
32	Cement	Grade 43/53 of L&T/A.C.C./Ambuja/Ultratech
33	White Cement	Birla cement/JK cement
34	ACP Panels/Sheets	Alubond/ALU Décor/Alstrong/Alstone
35	Flush door	Sonear/Century/Green
36	AC grill	Air products/omicron/patrawala
37	Melamine polish	MRF/Nerolac
38	Ball Catch	Magnetic (M-2)/ Brass or Equivalent

The above material list is only indicative and equivalent material may be used. Prior Approval from Bank / Architect to be obtained for any material to be used at site.

NOTE:-

- 1. In case of unavailability of any material of specific make an equivalent make can be used only after a written approval of the Architect / Bank. The preference of make/brand of the material listed above will be decided by the Architect/ Bank. The make/brand of any item will be as mentioned in the drawings issued by the Architect.**
- 2. The contractor shall provide samples of all materials mentioned in the list of makes as required by the Architect. A written approval of these samples shall be sought prior to commencement of any work. Architect / Bank reserves the right to enquire the genuineness of any material used at site directly from the manufacturer/dealer.**

LIST OF APPROVED AND NOMINATED MANUFACTURERS / SUPPLIERS OF ELECTRICAL MATERIALS FOR INDIAN BANK AT MODI NAGAR STATION ROAD BRANCH , GHAZIABAD, UTTAR PRADESH.

S.NO.	MATERIALS	APPROVED BRANDS
1	PVC fittings	Polycab/ AKG / Precision
2	Wires – PVC insulated copper	Finolex/Polycab/Havells
3	Cables (armored)	Gloster / Havells/ Polycab
4	A.C Starter, Plug Socket	Crabtree / Northwest/ Legrand
5	Light & Power switch socket	Crabtree / Northwest /Philips
6	Telephone Socket	RJ-11 Crabtree/ Philips/MK
7	DB MCB	Legrand/ Hager/ Schneider
8	MCB	Legrand/ Hager/ Schneider
9	Telephone cable	D-Link / Delton / AMP/Dowel
10	Light fitting	PHILIPS/Wipro/Panasonic
11	Fuse Switch	L&T / Havell's
12	Telephone Connector	Corn
13	Ceiling/ Wall fan	Crompton / Orient / Havells
14	Exhaust fan	Crompton / Orient / Havells
15	P.V.C tape	Steel Greep
16	Call bell	Max
17	Cable Lug	Dowell's
18	Cable gland	Comet/ Gripwel/ Dowel
19	Distribution board	L&T/ABB/Legrand
20	MS conduit	BEC/ Precision/ AKG
21	Starter & single phasing preventer	SEIMENS
22	SPN, TPN, Sheet metal	Havell's / Legrand/ L&T
23	Pipe Metal	M.S Conduit 16 S.W.G

24	Metal Pipe Fittings	Cast iron with thread & inspection cover
25	Pipe PVC (Rigid Conduit)	AKG / Polypack/Precision
26	PVC fitting for Rigid	-Do-
27	PVC Roll Pipe	Super Dalda or equivalent heavy guage
28	PVC Casing & Casing Fittings	Good quality heavy guage (colour white)
29	Lugs	Dowel/Braco/Nettlefold
30	Terminals	Essen/Elmex
31	Burglar alarm	Godrej/ Globe detective
32	E-cat 6 Patch panel	Schneider Electric/ Avaya
33	P.A. System	Bosch/ Ahuja
34	UPS wiring	Crompton/KEI
35	Aluminum ducting sheet	Jindal/ SAIL
36	AC	Voltas, Daikin, Blue Star.
37	Timer	Legrand
38	Cat-6 cable/Cat-6 I/O	D-Link/Molex

The above material list is only indicative and equivalent material may be used. Prior Approval from Bank / Architect to be obtained for any material to be used at site.

NOTE:-

1. In case of unavailability of any material of specific make an equivalent make can be used only after a written approval of the Architect / Bank. The preference of make/brand of the material listed above will be decided by the Architect/ Bank. The make/brand of any item will be as mentioned in the drawings issued by the Architect.

2. The contractor shall provide samples of all materials mentioned in the list of makes as required by the Architect. A written approval of these samples shall be sought prior to commencement of any work. Architect / Bank RESERVE the right to enquire the genuineness of any material used at site directly from the manufacturer/dealer.

**LIST OF APPROVED AND NOMINATED MANUFACTURERS / SUPPLIERS OF AC
WORK MATERIALS FOR INDIAN BANK AT MODI NAGAR STATION ROAD
BRANCH , GHAZIABAD,
UTTAR PRADESH.**

S.NO.	MATERIALS	APPROVED BRANDS
1	AC UNIT (Split AC and Cassette AC) 3 star rating 2021-22, AC should have copper condenser only.	Voltas, Daikin, Blue Star.
2	Copper piping with Installation (Superlon Malysiau)	Rasco/ Mandev/Mettuble.
3	Voltage Stabilizer	Voltech/ Logicstat / V-guard.
4	Interconnection cable $\frac{3}{4}$ core between indoor to outdoor units	Johnson / National/ Kalinga.
5	Drain pipe	UPVC drain pipe 25mm with elbow socket and T(Make - Prince or Equivalent)

SUMMARY OF BOQ FOR INTERIOR FURNISHING WORK AT INDIAN BANK, MODINAGAR

A	SCHEDULE - 'A'	
1	INTERIOR FURNISHING WORK	
2	ELECTRICAL WORK	
3	AC WORK	
		TOTAL
	* GST EXTRA AS APPLICABLE	

BOQ FOR FURNISHING WORKS AT INDIAN BANK, MODINAGAR

S.NO.	DESCRIPTION OF ITEM	QTY	UOM	RATE (Rs.) (Excl. GST)	AMOUNT (Rs.) (Excl. GST)
1	PARTITIONS				
	Frame Work: Providing and fixing in position Full Height partition in framework of 600 X 600 mm grid (horizontally and vertically) comprising of 50mm X 50mm heavy duty GI Box Sections (1.6 mm) with 8 mm thick ply on both sides finished with 1 mm thick laminate as mentioned below.				
	Note: a) In case of false ceiling, the vertical GI members to be fixed to RCC ceiling but the area of partition payable will be below the false ceiling only. b) Measurement of height shall be taken from finished floor only, in case of varying heights on either side of partition, average height shall be considered. c) Openings/ door/ glass shall not be measured for payment and shall to measured and paid under seprate relevant item.				
	Laminate: 1.0 mm thick matt laminate (shade and design as per Bank's Scheme) pasted over MDF with approved adhesive. Laminates shall be combination of 2 or more colour as per bank's guideline to be approved from the bank prior to application. Partition shall have 100mm high skirting from the finished floor in Bank's approved colour and a 100mm high top band from the soffit/ceiling/visible top of the partition in Bank's colour scheme. Remaining Area to be covered with laminate				
	The necessary openings and provisions in the frame work for Electrical Conduits, modular electrical boxes, AC Grills & pipes, AC Ducts / louvers, doors / glazing etc. should be provided as per site requirements while keeping the structural integrity and strength of the framing intact. The GI frame members shall be fixed rigidly to the floor, columns, RCC Ceiling and beams. Note: In case of false ceiling, the vertical GI members of the frame should be fixed / screwed / grouted rigidly on the Roof / RCC ceiling but the area of partition payable will be measured from the finished floor up till the false ceiling only. In case of varying heights on either side of partition, average height shall be considered.				
1a	Manager Cabin Partition (Partly Glazed - Full Ht.)	195.00	Sq. Ft.		

	<p>Proving and fixing both side laminated partly glazed partition using framing, MDF and laminate as per details mentioned in Sr. No.1. The partition shall be solid till 3'-6" height and glazed with 6mm thick clear float glass in size 3'-6" (H) & 4'-0" (W) or of appropriate size as per site requirements. All sides of the glazing must be provided with teakwood beading on both faces and finished with 2 coats of melamine polish. Solid partition to be provided over the fixed glazing till soffit of false ceiling / roof / RCC Ceiling. All exposed edges shall be fixed with lipping of appropriate thickness enough to cover the entire exposed edges and frame opening for fixed glazing / doors chowkhat / windows (75mmx75mm thick sections or as per site) with 2 coats of melamine polish. The rate quoted must be inclusive of the 32-35mm thick door (Size - 7'-0" X 3'-0") made with commercial plywood / board of approved make with 1.0 mm thick matt finish laminate pasted over plywood along with skirting and top band on both sides of the door as per bank's colour scheme along with making 8-10mm glass opening of size 18"(W) X 48"(H) positioned at the horizontal centre & 5'-0" height for visibility with proper teakwood framing and polishing. The exposed edges of the door must be finished with teakwood lipping with 2 coats of melamine polish. Item shall also include supply and installation of frosting film of aproved make with approved artwork. Film shall be of approved make, self-adhesive with bubblefree installation to be done on clean glass. The rate quoted must also include installing / affixing all necessary fittings like 4 Nos. SS Butt Hinges (100mmx5.5mm size), screws, Hydraulic Door Closer, Mortise Lock Assembly, SS Handles on both sides & Brass Door Stopper etc as per approved makes.</p>				
1b	Cash Cabin Partition (Height 7'-6")	210.00	Sq. Ft.		
	<p>Proving and fixing both side laminated Solid partition for cash cabin using framing, MDF and laminate as per details mentioned in Sl. No.1. The partition shall be solid till 4'-0" height and thereafter an opening of 2'-6" Height & 2'-6" width (or of appropriate size as per site requirement) for Aluminium Decorative Grill (12mm thick having hexagonal openings) which shall be provided with double sided 2 coat melamine polished teakwood beading. Rest of the height shall be solid partition till the height of 7'-6" from the finished floor. All exposed edges of MDF shall be fixed with teakwood lipping of appropriate thickness (75mmx75mm thick sections or as per site) enough to</p>				

	cover the entire exposed edges and frame opening for aluminium grill / doors chowkhat / windows etc.) with 2 coat melamine polish.				
	The rate quoted must be inclusive of the 32-35mm thick door (Size - 7'-0"x3'-0") made with commercial plywood / board of approved make with 1.0 mm thick matt finish laminate pasted over plywood along with skirting and top band on both sides of the door as per bank's colour scheme along with making 6mm thk glass opening of size 18"(W) X 48"(H) positioned at the horizontal centre & 5'-0" height for visibility with proper teakwood framing and polishing. The exposed edges of the door must be finished with teakwood lipping with 2 coats of melamine polish. Item shall also include supply and installation of frosting film of aproved make with approved artwork. Film shall be self-adhesive with bubblefree installation to be done on clean glass.				
	A 2" deep slip tray made of 11mm/12mm MDF covered with 1.0 mm thick laminate with edges finished with teakwood beading and 2 coats of melamine polish to be affixed at a height of 4'0" from the finished floor on the side partition adjacent to the passing Officer's counter at an appropriate slot to ensure convenient usage by both staff members. The slip tray must be 6" wide 10" long and must be positioned such that it must be emanating 4" on either side of the partition. The front edges of the partitions i.e., the edges visible to the customers, shall be finished with 1.0mm thick laminate of Bank's approved colour . The rate quoted must also include installing / affixing all necessary fittings like 4 Nos. SS Butt Hinges (100mmx5.5mm size), screws, Hydraulic Door Closer, Night latch, SS Handles on both sides & Brass Door Stopper etc as per approved makes.				
1c	Low Height Partition (Height 4'-0") - Between working Counters, cubicles & support for Flap door)	151.00	Sq. Ft.		

	<p>Proving and fixing both side laminated solid partition using framing, MDF and laminate as per details mentioned in Sl. No.1. The partition shall be solid till 3'-0" then glazing with 8-10mm thick clear float glass of 1'-0" Height & supported on 4" wide solid partition pillars on both sides of the glass. The exposed edges of the glass shall be bevelled, grinded and machine finished to render smooth edges. The glass in the partitions shall be fixed with beading / moulding on both sides. All exposed edges of partition shall be fixed with teakwood lipping of appropriate thickness (75mmx75mm thick sections or as per site) enough to cover the entire exposed edges and frame opening for fixed glazing / doors / windows) with 2 coat melamine polish. Item shall also include supply and installation of frosting film of aproved make with approved artwork. Film shall be self-adhesive with bubblefree installation to be done on clean glass.</p>				
	The length of the partitions between the counters shall be 3'0"				
1d	Solid Partition (Full Ht.) - Both Side Laminated	122.00	Sq. Ft.		
	<p>Solid partition including Strong Room partiotion up to 7'6" height:- Proving and fixing both side laminated solid partition using framing, MDF and laminate as per details mentioned in Sr. No.1. All exposed edges of partition shall be fixed with teakwood lipping of appropriate thickness enough to cover the entire exposed edges and frame opening for doors chowkhat (75mmx75mm thick sections or as per site) with 2 coats of melamine polish. The rate quoted must be inclusive of the 32-35mm thick door (Size - 7'-0"x3'-0") made with approved plywood / board of approved make with 1.0 mm thick matte finish laminate pasted over plywood along with skirting and top band on both sides of the door as per bank's colour scheme. The rate quoted must also include installing / affixing all necessary fittings like 4 Nos. SS Butt Hinges (100mmx5.5mm size), screws, Hydraulic Door Closer, Mortise Lock Assembly, SS Handles on both sides & Brass Door Stopper etc as per approved makes. The exposed edges of the door must be finished with teakwood lipping with 2 coats of melamine polish.</p>				
1e	Solid Partition (Full Ht.) - Cement Fiber Board for UPS Room and electrical panel	225.00	Sq. Ft.		

	<p>Providing and fixing both side solid partition using framing and laminate as per details mentioned in Sl. No.1. The skin of the partition shall be made out of 10mm thick cement fiber board and finished with 1mm thick laminate of approved shade and scheme on the customer side (visible to customers) and 2 coats of ivory white enamel paint on the internal side (not visible from the customer lobby). The rate quoted must be inclusive of the providing one pane door for UPS room (Size - 7'-0" x 2'-9") & 2 panes door (Size-7'-0" x 2'-0" for electrical panel) or door sizes as per site requirements in combination of 6mm thk cement fibre board and 19mm thick approved block board pasted / screwed together to form a single entity and finished as per matching scheme. The block board shall be on the outer side and shall be pasted with 1.0 mm thick matt laminate along with matching skirting & top bands as per bank's scheme and the cement fiber side of the door shall be on the inside with 2 coats ivory white enamel paint over a coat of primer. Exposed edge of door thickness shall be finished with teakwood lipping & melamine polish.</p>				
	<p>Item shall include installing / affixing 12" X 6" aluminium louvers at the horizontal centre of the door panes at suitable height along with all other necessary hardwares & fittings such as 4 Nos. SS Butt Hinges (100mmx5.5mm size), screws, mortice lock / brass tower bolt, SS Handles on both sides, magnetic ball catchers etc of approved makes.Note - For the purpose of contractor's payment in case of Electrical panel cabinet, only front elevation area shall be measured. BUT the partition shall be erected till soffit of the actual ceiling along with the board concealing the entire area and not just till the false ceiling.</p>				
1f	Single Skin Partition Bove False Ceiling	40.00	Sq. Ft.		
	<p>As of the above but Providing and fixing single skin partition above false ceiling(where false ceiling is provided only on one side) for a height of up to 600mm or near about soffit of roof using aluminium frame as specified above along with 6mm thick Commercial ply wood lined on only one side and lining with 1mm thk laminate of approved shade and amke along with grooves.</p>				
1f	Flap Door (4'0" High)	24.00	Sq. Ft.		

	<p>Providing and fixing of flap door using 19mm thick block board of approved make laminated on both sides with 1mm thick laminate of approved shade as mentioned above. The exposed edges of the board shall be finished with teakwood beading of appropriate thickness (enough to cover the entire exposed edges). The rate quoted must also include a vertical brass tower bolt assembly, 2 Nos. SS Butt Hinges (100mmx5.5mm size), screws & magnetic ball catchers etc of approved makes. There shall be 100mm high skirting at the bottom of the door with 1mm lamination in Bank's approved colour & a 100mm high top band of Bank's Approved colour at the vertical top of the door so as to match the surrounding scheme.</p>				
<p>2</p>	<p>COUNTERS & TABLES</p>				
	<p>Providing & Fixing Box type Tables and counters of size mentioned below as per branch drawing and layout. The tables / counters are made out of 19mm thick approved ply / block board frame work for top, verticals, apron, sides, drawer unit with shelves, shutters, customer top, foot rest. The sides, sliding shutters, front apron of drawer unit shall be made out of 12.0mm thick approved ply while backs & bottom of drawer unit shall be made with 6mm thick approved ply. The drawer unit of 450mm width x 750mm height x 500mm depth or size approved by the bank shall be placed on a suitable side of the table / counter as per layout. The drawer unit shall consist of 3 nos. drawers of equal height to cover the entire height of the unit & each must be 450mm deep OR of size & number as approved by the bank. Each drawer shall have SS handles with multipurpose concealed lock. The drawers shall be fixed with telescopic SS sliding channels of approved make with easy push-pull mechanism.</p>				
	<p>A uniform 100mm high skirting shall be provided at the visible bottom of the side unit with 1.0mm thick laminate of Bank's approved colour . A fixed footrest made with T.W. member of size 4"X1.5" finished with french polish shall also be provided at the bottom of the inside of the tables / counters at a comfortable height. The working top of ALL counters / tables shall be provided with 10mm thick clear glass on top with edges bevelled and machine finished to render smooth edges. Grooves / openings for cable managers shall also be provisioned in the table and glass along with supply & fixing of cable manager. The shape of the top glass shall be prepared / cut in such a manner</p>				

	that the entire surface of the working top of the table / counters should be covered by the top glass.				
	All the open surfaces of the tables / counters / drawer units shall be completely covered with 1mm thick laminates. The front apron and visible side apron(s) of the counters / tables shall be provided with 100mm top band of 1.0mm thk laminate of Bank's colour scheme & 100mm skirting of of 1.0mm thk laminate of Bank's approved colour . The remaining area shall be provided with 1.0mm thick laminate The counter / table top shall be provided with 1.0mm thick laminate of Bank's approved colour . The other exposed edges shall be finished with teakwood lipping & 2 coats of melamine polish. All inner surfaces shall be finished with approved 0.8 mm thick laminate of ivory / white shade of approved make.				
	All table / counters shall be provided with sliding key board unit of size 12"x20" made of 19mm thick approved board finished with 1.0mm laminate and mounted with telescopic channels of approved make on the sides made out from 12mm thk approved board with 1.0mm thick laminate All exposed edges to be finished with teakwood beadings of appropriate size and 2 coats of melamine polish along with all other finishes / hardware / fittings etc required to complete the job.				
	For CASH COUNTER- Same as above but the cash counter shall have two working tops viz. one working top at height of 2'-6" for staff & other, the customer top, at height of 4'-10" for customer use. The customer top shall be 450mm wide of length as mentioned below and shall be fabricated such that it is projected 150mm outwards i.e. towards the customer. The rate quoted must include full front portion and customer top of mentioned height and style made out of 19mm approved ply and 1.0mm thick laminate of design as approved by the Bank, along with 10-12mm plain float front glass which should be 3'-0" high over and above the customer top and of required length as mentioned below. A support partition shall also be provided on top of the glass till a height of 7'-6" from the finished floor. The partition over the glass shall be made out of 19mm thk approved board finished with 1.0mm thick laminate of Bank's approved colour . The front glass shall be fixed rigidly over the customer top with teakwood beadings on both sides finished with 2 coats of melamine polish. Two openings / slits shall be provided in the front glass - one opening of 300mmx150mm on the horizontal centre at the bottom of the glass and another 3" wide horizontal slit				

	at the vertical centre of the front glass for convenient cash and voice transaction. The glass edges shall be bevelled on all exposed edges on both faces to ensure safe & smooth edges.				
2a	Branch In-charge Table (Size: 6'0"x3'0"x2'6"(H))	1.00	No.		
2b	Officer Table (Size: 5'0"x2'6"x2'6"(H))	5.00	No.		
2c	Staff Counters (Width of working top: 2'6"; Height: 2'6")	15.00	R. Ft.		
2d	Cash Counters (Width of working top: 3'0" & width of customer top: 1'6"; Heights as per description above)	10.00	R. Ft.		
3	STORAGE CABINETS / CREDENZAS				
	<p>Providing & placing in position box type storage cabinets / Credenzas 18" deep & height as given below made out of 19mm approved board with 1mm laminate with shade as per bank's approved scheme. The top of the low height storages / credenzas shall be finished with 1.0mm thk Bank's approved colour. The sides, partition, top, shelves & bottom shall be made out of 19mm thk. approved board and back made out of 6mm thk. approved ply. Item shall have one 6" high drawers on top made out of 19mm thick approved ply / board complete with handles, locks etc of approved makes. The shutters made out of 19mm commercial ply wood finished with 1.0mm thk laminates of approved scheme on the outer surface shall cover the remaining space available below the drawers. All inner surface shall be finished with 0.8mm thick laminate with matching edge tapes for all exposed edges. A 100mm high top band shall be provided on top front face of the storage cabinets / credenzas finished with 1mm thk Bank's approved colour shade & 100mm high skirting finished with Bank's approved colour shall be provided as per approved make.</p>				

	<p>The drawer must be finished with 1.0mm thk laminate of shade as per Bank's scheme on outer surface and 0.8mm thick laminate on the inner surfaces. The drawers shall be supported with SS telescopic sliding channels of approved make with smooth push-pull mechanism along with SS handles and individual locks. The shutters below the drawer shall be supported with soft close clip-on SS Hinges of approved make of required number depending upon the size of the shutter. Each shutter shall be supplied with necessary accessories and hardware such as individual locks, SS handles, magnetic ball catchers, SS tower bolts, individual locks etc. of approved makes screwed and fixed rigidly. Horizontal shelves & vertical planks made out of 19mm thick commercial board shall be provided inside the shutters in such a manner to create optimum number of storage chambers each of equal storage space depending upon the size of the cabinets / credenzas. These partiotions shall be finished with 1mm thick laminate on all faces and exposed side (thickness) edges of the partition members shall be finished with teakwood lipping and 2 coats of melamine polish.</p> <p>Note - For the purpose of contractors bill payment, only front elevation area shall be measured</p>				
3a	Side credenza adjacent to the tables and counters (2'-6" High & 3'-0" Wide OR as mentioned in layout) Same as Sr. No.3 but with 1 no. 6" high drawers at top & shutters below drawer.	45.00	Sq. Ft.		
3b	<u>Low Ht. Storage (2'-6" High) (FOR B.M. Cabin and select staff in branch hall only)</u> Same as Sr. No.3 but with 1 no. 6" high drawers at top & shutters below drawer.	83.00	Sq. Ft.		
3c	<u>Low Ht. Storage (4'-0" High) (FOR space behind staff counters in Branch Hall only)</u> Same as Sr. No.3 but without drawers & with shutters fitted with SS butt hinges, vertical and horizontal shelves of appropriate size to utilize the entire space available as per layout for creating optimum space inside storage chambers at different heights.	0.00	Sq. Ft.		
3c	<u>Full Ht. Storage (8'-6" High) (FOR space behind staff counters in Branch Hall only)</u> Same as Sr. No.3 but without drawers & with shutters fitted with SS butt hinges, vertical and horizontal shelves of appropriate size to utilize the entire space available as per layout for creating optimum space inside storage chambers at different heights.	0.00	Sq. Ft.		
4	Aluminium Partitions & doors				
4a	AL. PARTITION:	0.00	SqFt		

	Providing & fixing Aluminium powder coated frame of sections 1.75" X 1.75" of 16 gauge (1.6mm) or higher thickness and 6 mm thk clear fixed glass. Item shall include all fixtures & fittings like neoprin rubber beading, springs etc complete. Item shall also include supply and installation of frosting film of aproved make with approved artwork. Film shall be of approved make, self-adhesive with bubblefree installation to be done on clean glass.				
	In case a ceiling type formation is to be prepared for enclosing the entrance vestibule of the branch / ATM from top due to avoid site nuisance of dust, pests etc where false ceiling is not carried out, the top of the partition vestibule shall be fabricated with aluminium frame as above and finished with approved make pre-laminated board panels of bank's approved shade on the visible surface. <u>Note</u> - The additional ceiling partition item (if carried out) shall be measured on plan area and shall be added to the partition item quantity.				
4b	AL. DOOR	0.00	SqFt		
	Providing and fixing of Aluminum door with powder coated Aluminum sections of size 3.25"X 1.75" for door opening size of 2 x 2'-6" x 7'-0" in double panes (Branch entrance) & 1 x 2'-9" x 6'-6" (ATM Entrance) in single pane or as per drawing. Item shall include providing & fixing in position 6mm thk clear glass on door panes with bank's logo & frosting film of aproved make with approved artwork. Film shall be of approved make, self-adhesive with bubblefree installation. Item shall also include all the required hardware & fittings of approved makes such as heavy duty floor spring, D type matt finish SS handles of size 1'-3" of both sides of the door, 3 round dead lock arrangement, tower bolts of matching colour, self-adhesive push-pull indication stickers on both sides etc complete.				
5	CUSTOMER WRITING DESK.	1.00	No.		

	Supply and fixing of free-standing box type customer writing desk of required length, 42" height and 18" deep. The desk shall be made out of 19mm thick approved block / ply upto the height of 36" and glass bins above (open towards the front for keeping challans) of size 6" X 6" each made up of 10 mm thick plain glass on back & side partitions of the bins affixed firmly to the base and the writing top over the bins shall be made of 12mm thk clear glass, finished with smooth edges and sealed with silicon sealant. The bottom of the desk shall consist of 2 nos. box type cabinets of size - 12" (w) x 24" (h) x 18" (d) made out of 19mm thick approved ply with shutters with a viewing glass pane of appropriate size using 6-8mm plain glass and 20mm horizontal slit at the top of the shutter. The shutter shall be complete with all accessories like lock, SS handles, SS Hinges etc. All the exposed surfaces of the board shall be covered with 1mm thk laminate of approved shades and exposed edges to be finished with teakwood lipping and 2 coats of melamine polish.				
	The exterior visible portion of the desk shall be finished with 1.0mm thick approved laminate on visible sides as per bank's colour scheme with matching top band skirting . All inner surfaces shall be finished with approved 0.8mm thk laminate in white shade. Item shall include all required hardware & accessories such as SS clamps, screws, slits etc to ensure that the rigid fixing of the desk members / parts and complete the item upto the satisfaction of the bank / Architect.				
6	SOLID DOORS-IN LAMINATE FINISH (with hardware fittings MAKE EVERITE/GOLDEN /HARDWIN/EVEREST) (WITH OR WITH OUT VISION PANEL AS PER DIRECTION OF BANK / ARCHITECT	0.00	Sq.Ft.		
	3-0" x 7'-0" - IN LAMINATE FINISH - (WITH 2" x 3.5" finished size WOODEN FRAME)				
	Providing and fixing solid doors of sizes as shown in the drawing. The door shutter shall of 35 mm thick flush shutter of approved make and finished with 1mm thick approved laminate on both sides. The edges finished with steam beach lipping. A door frame of 3.5" x 2" steam beach section shall be provided finished in mellamine. Rate shall include Dead lock (Godrej Make), floor springs / door closure (as the case may be), door stopper, a pair of handles 12" SS Brushed finished, 5" hinges 4 Nos., buffers, tower bolts, etc with necessary hardware items and with or with out door frames as mentioned above				

7	ENTRANCE DOOR - IN TOUGHENED GLASS	50.00	Sq.Ft.		
	DOORS - WITH OZONE / HAFFLE / YALE / GODREJ MAKE FITTINGS				
	Providing and fixing frameless fully glazed 12mm thk toughened glass door fixed with necessary patch fittings(Dorma/Ozone/Haffle/Yale/Godrej make) including cutting, making holes, cutouts in the glass of required shape and size to accommodate fittings and fixing the fittings in floors, soffits, jams including necessary fixtures, screws, sealant wherever required and SS cover over patch fittings. Rate shall include necessary etching film / LOGO, approved patch fitting locking systems, 1 pair of 12" long S. S. (C Shape) Handles of approved make, floor springs, and any necessary hardware items.(ABOVE MENTIONED MAKES Top Pivot , Top Patch Fittings, Bottom Patch fittings , Floor Spring , Corner lock with strike plate and Euro Profile Cilinder, C Shape Handle 25mm dia X 300mm length)				
8	FULLY GLAZED PARTITION - WITH TOUGHENED GLASS	92.00	Sq.Ft.		
	USING OZONE / HAFFLE / YALE / GODREJ MAKE FITTINGS				
	Providing and fixing of Fixed Glass partition with 10mm thick toughened glass using Standard fittings of above - mentioned makes at the top and grouting at the bottom with U - Shaped Aluminium rails and EPDM gaskets including cutting, making holes in glass and fixing the fittings in floors, false ceiling etc. and making the same good with necessary screw, sealant wherever required. The top fittings to be fitted to the Wooden section fixed above the Gypsum board in the level of GI channels of False ceiling.				
9	LOGO BOARDS FOR COUNTER FRONT ELEVATION	0.00	Nos.		
	Supplying and fixing logo boards on the front elevation laminated surface of counters with 5mm thick acrylic sheet of size 18" x 18", attached with SS glass studs (1" or more). Stickers with bank logo (colour and shape as per Bank scheme) in the center to be pasted on the back side of the acrylic sheet neatly without any bubbles. The logo board must be placed on the centre of the front elevation of the counters visible to the customers EXCEPT on the Branch Manager's Table.				
10	GLASS BARRIER	35.00	Sq. Ft.		

	<p>Providing and fixing glass barrier in the front of clerical / working counters made out of 10mm thick clear float glass with chamfered and polished edges. The glass must be supported at each end of the individual counters either with low ht. partitions or 3"x3" square towers of required height made with 19mm thick approved ply finished with 1mm thick laminate of approved shade on all faces as per the design approved by bank. In case of square towers, the top of the towers should be finished with 1mm thk approved laminate. The glass should be clamped rigidly to the low ht. partition / towers with teakwood beading finished with melamine polish along with necessary hardware / accessories as required. The height of the glass barrier shall be 450 mm (or as directed by the bank). The length of the glass barrier in single piece must be equal to the length of the individual counter. Item shall also include frosting film of aproved make with approved artwork. Film shall be of approved make, self-adhesive with bubblefree installation.</p>				
	<p><u>There shall be 2 uniform slits, each 75mm high; one at the bottom of the glass barrier just above the counter / Table top & one at the vertical centre of the glass barrier.</u></p>				
11	PANELING				
11a	<p>WALL / COLUMN PANELING (Full Ht. - till soffit of false ceiling) (IN ATM Room / Walls in Manager Cabin / Walls in Cash cabin / Independent pillars in branch hall / Side wall adjacent to Officer Table ONLY)</p>	345.00	Sq. Ft.		
	<p>Providing and fixing in position wall panelling in 600 X 600 mm grid (horizontally and vertically) comprising of 25 mm X 50 mm heavy duty GI Box Sections (1.6 mm) with 8 mm thick ply finished with 1 mm thick laminate finish of approved shade and make. The soffits of the doors / windows shall also be covered with paneling as well. Item shall include 100mm high skirting on bottom of the finished floor in Bank's approved colour and a top band of 100mm high from the soffit/ceiling/visible top height of the paneling in Bank's colour scheme. Remaining area shall be finished with 1.0mm thk laminate of approved make. Note - No paneling shall be provided behind the storage / cabinets / tables sides or any other surface which is not visible (no payment for same shall be entertained by the bank). Entire paneling shall be provided only on visible surfaces as per approved layout or as directed by the Bank. Also, no paneling</p>				

	shall be provided on the columns embedded in walls. The paneling should be provided on independent pillars in the branch hall only that too till soffit of false ceiling.				
	Note:- In case of wall not being true to plumb extra shims of aluminium section shall be provided. Nothing extra shall be payable in this regard.				
	Note: a) In case of false ceiling, area of panelling payable will be below the false ceiling only. b) Measurement of height shall be taken from finished floor only, in case of varying heights on either side of panelling, average height shall be considered. c) Openings/ door/ glass shall not be measured for payment.				
12	FALSE CEILING (Branch & ATM)	895.00	Sq. Ft.		
	Providing and fixing ½" thk. Gypsum India board false ceiling at levels as shown in the drg. From FFL. Rate shall be inclusive of all Gypsum India components contained G.I. perimeter channels of size 0.55 thick having one flange of 20mm and another flange of 30mm and a web of 27mm alongwith perimeter of ceiling, screw fixed to brickwall/partition with the help of nylon sleeves and screws, at 610mm centres. The suspending G.I.intermediate channels of size 45mm, 0.9mm thick with two flanges of 15mm each from the soffit at 1220mm centres with ceiling angle of width 25mm x 10mm x 0.55 thick fixed to soffit with G.I. cleat and steel expansion fastners at every 610mm c/c. Ceiling sections of 0.55mm thickness having knurled web of 51.5mm and two flanges of 26mm each with lips of 10.5mm are then fixed to intermediate channel with the help of connecting clip and in direction perpendicular to the intermediate channel at 457mm centres. 12.5mm tapered edge Gypboard is then screw fixed to ceiling section with 25mm drywall screws driver or drilling machine with suitable attachment. The boards are to be jointed and finished so as to have a flush look which includes filling and finishing the tapered and square edge of the boards with jointing compound & joint paper tape. Rate shall be inclusive of Cut outs for A/c machiness, spot lights, light fixtures, A/C. Grills, fire and security systems cut outs, All Sections should adhere to the manufacturers guidelines. Vertical sides visible will be measured.				
13	MODULAR FALSE CEILING - ARMSTRONG / equivalent make	1,076.00	Sq. Ft.		

	Providing and fixing Armstrong (Fine Fissured Micro Look with Tagular Edge using 15mm Grid sections) false ceiling of size 24"x24" at levels as shown in the drwng. from FFL. Rate shall be inclusive of providing the total system with installation etc.. The contractor has to maintain all tiles in good order and replace the defected tiles (at his own cost) before handing over the site for Branch Operations (till Inauguration).				
13	GLASS SHELVES	0.00	Sq. Ft.		
	Providing and fixing glass panes / shelves of required sizes with all edges neatly grinded, polished and fixed to the wall surfaces using SS D-brackets. The glass shall be 10mm thk plain glass of approved make. Item shall include all required arrangement / hardwares/ accessories to complete the job upto the satisfaction of bank / Architect. <u>Note</u> - For the purpose of contractor's payment, front elevation area shall be measured.				
14	CHEQUE DROP / SUGGESTION BOX (with glass front)	2.00	Nos.		
	Supplying and fixing wall mounted Cheque Drop Box of outer size 10" (D) X 12" (W) X 20" (H) with front openable partly glazed shutter, lock, slot for dropping cheques from top along with all required hardwares & accessories like SS handle, SS butt hinges etc to complete the job upto the satisfaction of the bank / Architect. The box shall be made out of 12mm thk approved plywood finished with 1mm thk approved laminate on outer faces & 0.8mm thk laminate on all inner faces. The front door shall have 6mm thk glass of size 6"x12" fixed with beach wood beeding. All exposed edges of Plywood shall be fixed with teakwood lipping of appropriate thickness enough to cover the entire exposed edges with 2 coats melamine polish. The box shall be complete with all accessories like SS hinges, SS Handles, Locks etc of approved makes.				
15	NOTICE / PIN-UP BOARD	1.00	Nos.		
	Providing & fixing Notice Board made of tag board of approved make & design of size 4'-0" X 3'-0" with powder coated aluminum border / frame. The board should be 3/4" thk straw board with velvet type fabric covering of Bank's approved colour .				
16	ACP WALL PANELLING (For outside front walls and ATM only)	340.00	Sq. Ft.		

	Providing & fixing in position ACP (Aluminum Composite Panel) wall paneling having minimum ACP thickness of 3mm and minimum foil thickness of 0.25 mm on both sides with Aluminum framing tube sections of min 1.5" X 1" (20 gauge or down) @ 2'-0" C/C both ways. Panels shall be neatly fixed to the frame with 3M or equivalent adhesive and joints shall be finished with silicon-based sealant. ACP shall be of approved make and in Ivory & Bank's approved color as per bank's approval. Item shall include proving & fixing additional sections as required for fixing Indoor AC units, proper access panel for ATM power point, proper locking arrangement for plug point by providing additional framing etc. complete. Note - For the purpose of payment, the measurements shall be taken up to the visible height / false ceiling level only.				
17	BOXING FOR ROLLING SHUTTER	166.00	Sq. Ft.		
	Providing and fixing rolling shutter paneling / enclosure of required size as per description at Sr. No.9. The rate shall inclusive of necessary hardware fittings like hinges, screws, tower bolts sealant, trap door, locking arrangement etc complete.				
18	ALUMINIUM GRILL FOR BULK CASH COUNTER TOP	0.00	Sq. Ft.		
	Providing & fixing 7.5mm thick 48mm X 48mm opening size, white colour powder coated aluminium grill at the top of the cash cabin fixed with 8mm thick teakwood beadings of necessary width. All the exposed wood / beadings shall be neatly finished with 2 coats of melamine polish. All the accessories used shall be concealed type.				
19	DISMENTALING WORK				
	Removing/dismantling the existing furniture, table partitions panelling, doors etc. and dispose the derbis from the site to municipal ground. The rate shall include the transport charge. Providing Temporary arrangements for functioning of Branch throughout the course of completetion of renovation work including temporary shifting of workstations, counters, storages, tables, chairs etc. to enable smooth functioning of the branch during renovation all complete as per the instructions of Architect/ Bank's Engineer. NOTE: None of the old furniture items must be used for providing the temporary setup for functioning of the branch during the course of renovation	1.00	Job		

20	TEMPORARY ARRANGEMENT	1.00	Job		
	Providing Temporary arrangements for functioning of Branch throughout the course of completion of renovation work including temporary shifting of workstations, counters, storages, tables, chairs, Records/Dismantling if required if any (false ceiling etc) etc. to enable smooth functioning of the branch during renovation all complete as per the instructions of Architect / Bank's Engineer .				
21	PAINTING PLASTIC PAINT				
	Applying 2 Coat putty with primer and Providing and applying Plastic emulsion paint (asian) of approved make and shade on walls including scrapping off, preparing the base & applying 3 or more coats of approved make, color and shade to give an even and smooth surface on new work including necessary scaffolding, coat of cement primer etc. all complete as per direction of Bank. (only banking hall.)	0.00	Sq.Ft.		
22	EMULSION PAINT				
	Applying 2 coat of Plastic emulsion paint (asian) of approved make and shade on walls including scrapping off, preparing the base ect color and shade to give an even and smooth surface on new work including necessary scaffolding, coat of cement primer etc. all complete as per direction of Bank. (Other than banking hall.)	0.00	Sq.Ft.		
23	RELAMINATION WORK				
	Removing all old pasted laminate from existing Wooden furniture from all side without damaging other items & Providing and fixing 6 mm thk BWP plywood to both sides finished with 1.0 mm thk laminate, all exposed edges to be provided with TW lipping finished with melamine polish complete as directed by Architect				
23.1	OFFICER TABLE	0.00	Nos.		
23.2	BM TABLE	0.00	Nos.		
23.3	CASH COUNTER	0.00	Nos.		
23.4	RUNNING COUNTER	0.00	RFT		
23.5	PARTITION	310.00	SQ.FT.		
GRAND TOTAL (Excl. GST) (Rs.)					

BOQ ELECTRICAL WORKS FOR INDIAN BANK AT MODINAGAR					
B	SCHEDULE - 'B' (ELECTRICAL WORK)				
SL No	PARTICULARS	UNIT	QTY	RATE	AMOUNT
1	DISMENTALING OF EXISTING ELECTRICAL WORK AND DISPOSAL OF MALBA TO NEAREST MUNICIPAL GROUND INCLUDING TRANSPORTATION & PROVIDING TEMPORARY SETUP FOR THE FUNCTIONING OF THE BRANCH DURING RENOVATION. KINDLY NOTE, NONE OF THE EXISTING / OLD ITEMS ARE TO BE USED FOR PROVIDING THE TEMPORARY SETUP FOR THE BRANCH.	Nos.	1		
2	ELECTRICAL WIRING & EARTHING				
2.1	Supply,laying,connection & testing of light,fan point, wiring by 2x1.5mmsq(2x3/.029) +1x1mmsq PVC insulated, multistrand single core copper conductor FRLS wire maintating the colour code as per direction in PVC conduite of 20mm with ISI mark 1.5mm thickness to conceal in wall partition mending good the damage, complete with PVC circular box, bend to be done as per drawing including 3 point ceiling rows wherever required GI saddle to be used for fixing, metal flexible/PVC flexiable pipe may use if requied in partition wall. All PVC pipes should be with ISI mark. No joints will be allowed inside pipe, light, fan & plug point complete with modular type switch plate & MS box . rate Including the main circuite line 2x2.5mmsq+1x1.5mmsq earth PVC insulated Cu. Wire from DB to switch board, maintaining the colour code. Circuite line for lighting switch board & 6Amps plug board are to be drawn from lighting DB to Lighting board & plug point board (independent), 6/16 Amps plug point line are to be draw from power DB.as per DBschedule /SLD				
a)	1 light by 1 switch (ATM 1 No)	Nos.	54		
b)	2 light by 1 switch (for Branch 12 & ATM 2)	Nos.	20		
c)	Ceiling fan point with step type electronic regulator	No	1.00		
d)	Same as above, but for exhaust fan excluding regulator.	No	3.00		
e)	Same as above 5A Point in the switchboard itself. (for branch 7 No & ATM 1 No)	No	10.00		
f)	same as above Wiring for call-bell point including buzzer	No	1.00		
g)	Wiring (2x2.5mmsq+1x1.5mmsq from power DBs) for independant 6A multi pin socket along with 6A modular type switches housed in painted MS box (upto 3 independent plug points can be taken in one circuit). For Fan	No	8.00		

2.2	Supply and installation of modular type 2 nos 6A & multi pin sockets with 2 nos 6 Amp one way switch housed in MS box to be fixed in partitions or concealed in wall. The box shall be painted with 2 coats of enamel paint over a coat of red oxide primer including wiring for Raw power socket outlet using 2 R runs of 2.50 Sqmm and single run of 1.5 sqmm PVC insulated multi stranded single core copper conductor FRLS wire in 20mm PVC conduit to be laid in floor, partitions, etc. complete with all accessories (looping 2 sets of 2x6A socket outlet in one circuit-from DB) (Raw power). for counter	No	11.00		
2.3	Supply and installation modular type 16A, 5-pin socket with 16A one way switch housed in MS box to be fixed in partitions or concealed in wall. The box shall be painted with 2 coats of enamel paint over a coat of red oxide primer, the rate shall include wiring fusing 2R 4.0 sqmm & single run of 2.5 sqmm PVC insulated multi stranded single core copper conductor FRLS wire in 25mm PVC conduit to be laid in floor, partitions, etc complete with all accessories (for line printer : or optional).(upto 2 independent plug points can be taken in one circuit)	Nos.	15.00		
2.4	Supply and installation of power supply disconnection arrangement for strong room consisting of 1 no 10A DP MCB housed in manufacturer's powder coated MS box to be fixed inside the strong room and connected with 1 no 3-pin metal clad plug with 2 metre long 3 core 2.5 sqmm PVC insulated flexible copper conductor cable.	Set	1.00		
2.5	Acs electrification :-				
(a)	Supply and fixing 25 Amps 3-pin modular socket with 25 Amp one way switch with indicator (near AC indoor unit) housed in manufacturers MS powder coated box to be concealed in wall including Wiring using 2R 6.0 sqmm & single run of 2.5 sqmm PVC insulated multi stranded single core copper conductor FRLS wire in 25mm PVC conduit to be laid in floor, partitions, etc complete with all accessories. (for cassette unit AC units) -(from Stabilzer to IDU)Supply.	Nos	4.00		
(b)	Supply and fixing 25 Amp - 3 pin metal clad socket with plug controlled by a 25 Amp SP MCB (for Ac wall mounted stabilizers) housed in manufacturers MS powder coated box to be concealed in wall including Wiring using 2R 6.0 sqmm & single run of 2.5 sqmm PVC insulated multi stranded single core copper conductor FRLS wire in 25mm PVC conduit to be laid in floor, partitions, etc complete with all accessories. (for casstte AC units) from AC DB to Stablizer	Nos	4.00		
(c)	Supply and fixing 20A 3-pin modular socket with 20A one way switch with indicator (near AC indoor unit) housed in manufacturers MS powder coated box to be concealed in wall including Wiring using 2R 4.0 sqmm & single run of 2.5 sqmm PVC insulated multi stranded single core copper conductor FRLS wire in 25mm PVC conduit to be laid in floor, partitions, etc complete with all accessories. (for split AC units) - (from Stabilzer to IDU)Supply (2 Nos for ATM).	Nos	2.00		

(d)	Supply and fixing 20A - 3 pin metal clad socket with plug controlled by a 20A SP MCB (for Ac wall mounted stabilizers) housed in manufacturers MS powder coated box to be concealed in wall including Wiring using 2R 4.0 sqmm & single run of 2.5 sqmm PVC insulated multi stranded single core copper conductor FRLS wire in 25mm PVC conduit to be laid in floor, partitions, etc complete with all accessories. (for split AC units) from AC DB to Stabilizer (2 Nos for ATM)	Nos	2.00		
3	LAYING OF CABLE :				
3.1	Supply laying fixing main power with 50mm sq 3.5 core PVC insulated, PVC sheathed Alu. Conductor, 1100 v. grade armoured cable complete with 02 nos 8 SWG bear GI.wire as running earth .(Meter panel to Main Panel & Dgset to Main Panel)	Mts.	15		
3.2	End termination of 50mmsq 3.5 Core armoured cable, complete with brass cable gland , Alu. Lug, PVC tape.	Nos	4		
3.3	- Do - 3.5 x 16 sqmm with 02 nos 8 SWG bear GI.wire as running earth. for Light D.B	Mts	15		
3.4	- Do - 3.5 x 25 sqmm with 02 nos 8 SWG bear GI.wire as running earth. for POWER & A.C D.B , UPS & ATM	Mts	15		
3.5	- Do - termination of 25 & 16 Sqmm 3.5 Core	Nos	6		
4	Out door type glow sign board wiring :-				
4.1	Supply laying of main line with 2x2.5 +1x1.5 mmsq through MS conduite from main panal to glow sign board.	Mts	15		
4.2	Supply installation of 16 amps DP MCB at main entrance Glow sign board & With Electronic timer as required.	Set	1		
5	EARTHING STATION :				
(i)	Earthing installation as per I.E. rule conforming to IS 3043-1987 or its latest amendent by making earth station with 600x600x3mm (mini-mun) thick copper plate electrode to be installed such that is top edge shall be at a minimum depth of 3.3mts below ground level after preparation of ground with charcoal, sand ,& salt, connecting the 25x3mm thick copper lead in strip (upto 10 mts length) by bolting and brazing to the copper plate complete with Brass bolt of suitable length double nuts & washer including supply & fixing of 50mm dia 2.3Mts long partly perforated G.I. Pipe with funnel for watering arragment.				
	N.B :- <u>The Copper plate to be buried under 3.3Mts depth from ground level, including C.I. Pit 300x300mm with necessary brick wall (For UPS earthing).</u>	Set	2		
(ii)	Supply laying 2x8SWG copper bear wire from earth spike to main panal.(Electrolite wire)	Mts	30		

6	MAIN ELECTRICAL DISTRIBUTION				
	Main Panel (wall Mounted Type)				
	Supply, fabricating, assembling, internal- connection, testing & connecting with incoming, out going power cables & lines as required to complete the job of cubical type electrical panel made from 14SWG CRC. M.S. sheet with proper earthing terminal (Nut-bolt & washer) 02 No. outside of panel, same nut-bolt to tighten with internal earth busbar of panel situated inside loose wire box (on top portion of panel) On top side of panel cable entry arrangement to be done for incoming & out going of lines. Painting powder coating electrical grey/ seimensgrey to be done. one 6"x4" enamel type 440Volt Danger board to fix up on main panel bus-bar cover, components are as follows :-All switches are front handle operated & all MCB knob should be visual, all component to provide in separate compartment only DBs in one compartment.				
	Incomer - 100A 4P MCCB 25Ka with adjustable thermal & Magnetic trip unit -1 Nos				
	OUTGOINGS -				
6.1	63 Amps 4 pole MCB. = 04 Nos. (AC & Power DB, ATM, UPS, spare) 40 Amp 4 Pole MCB :2 nos (Lighting DB, Spare) 25 Amps DP MCB = 02 Nos. (sign board , Fire Alarm) Amps Meter 0-100 Amps with 3 Nos. CT & selector switch 96x96mm 01 Set (Changeover should be ON-LOAD type.)				
	100Amps 4pole Cu. Bus Bar. 01 Set. 100Amps 4 pole Change over switch. 01 No. 100 Amps FP MCCB 25KA as Gen - Set main incoming 01 NO.				
	Volt meter 0-500volt A.C. 50 Hz. 96x96mm with selector switch. AE make. n 01 Set				
	20mm dia LED indicator lamp 06 Nos.				
	02 Amps Sliding Fuse. 06 Set.				
	150x100mm enamel Danger board 440 volt.				
	(to set on bus bar cover). 01 No.				
	Cable entry from top & bottom - removable gland plates (bottom at 2 points) c/w powder coated Grey paint (two coats) with name labels for all incoming & outgoing feeders. The panel shall be complete in all respects including all accessories such as earthing bus, Air ventilators, lifting hooks etc.	Set	1		
6.2	POWER DB & AC DB. Make standard/Legrand/ABB 6 way TPN MCB DB with				
	63 TP&N MCB as main				
	16Amps SP MCB - 9 Nos+32AMPS SP X9 NOS.				
	including Neutral Bar. 01 Set	Set	1		
6.3	LIGHTING DB Make standard/Legrand/ABB				

	6 way TPN MCB DB with				
	63A TP&N MCB as main				
	16 Amps SP MCB - 03 Nos.+				
	10 Amps SP MCB - 09 Nos.				
	Including Neutral Bar. 01 Set	Set	1		
7	UPS SYSTEM (Branch)				
7.1	UPS Main DB Supply, erection, testing and commissioning of three phase 4 WAY, TPN MCB DB double door type with "C" Curve MCBs, IP 42 powder coated for UPS with 63A 4P MCBs - 1No as INCOMER 32A TP MCBs - 4 Nos. as OUTGOING Including all interconnections & accessories etc MAke standard/Legrand/ABB	Nos	1		
7.2	UPS DB-1 & 2 12 Way SPN MCB DB with 'C" curve MCBs. Incoming : 2 No. 40A DP MCB Outgoing : 4 Nos 6/10A SPO MCBs Make standard/Legrand/ABB	Nos	2		
7.3	Supply and installation of modular type 3 nos 6A multi pin sockets with 2 nos 6A one way switch with indicator housed in MS box to be fixed in partitions or concealed in wall. The box shall be painted with 2 coats of enamel paint over a coat of red oxide primer including making connections complete the rate inclusive of Supplying and running of 3 runs of 2.5 sq.mm UPS DB's to individual powerstation through .(looping 2 sets of 3X6 A socket outlet in one circuit / or as per SLD the following size of 660 volts grade, Finolex brand PVC insulated wire (For UPS point only).(For B.M. , Server & C.C.) & ATM 1 No. from separate ATM UPS.	Nos	17.00		
	TOTAL FOR ELECTRICAL DBs, WIRING, Etc	-	-		
		-	-		
8	ELECTRICAL FITTINGS (S/I/T/C				
8.1	2' X2' PLUTO NEO PANEL 4000K, CAT NO. LHEWEJP6PL 1W034, PHILIPS/WIPRO MAKE (ATM 2 No)	Nos.	26		
8.2	DOWNLIGHTER - INTEGRA 15W, 3000K, LHEBGTP5Z1W015, PHILIPS/WIPRO MAKE (ATM 2NOS)	Nos.	40		
8.3	TUBELIGHT - TITANIA SLEEK NEW T5 LED TUBELIGHT 18W, LHLDCNVENL8Z018, PHILIPS/WIPRO MAKE. ATM 1 No	Nos	8		
8.4	HANGING LIGHT - LHECDOL5PW1W040 (40WATTS), PHILIPS/WIPRO MAKE	NOS.	0		
8.5	225 mm dia Heavy Duty Exhust fan 230 voltA.C.(Havells / Crompton make).(UPS & Toilet)	Nos	3		

8.6	Wall mountaing fan FULL MS BODY 400 mm dia 230 volt A.C. PHILIPS/WIPRO MAKE	Nos.	8		
8.7	36" CEILING FAN WHITE COLOUR(ORIENT/KHAITAN).(UPS,Strong room & Store room)	Nos.	1		
8.8	Supply and fixing of LED strip light down lights in false ceiling. WIPRO GARNET D45027 (2700K) WW/with adopter	mtr.	0		
8.9	Supplying and fixing of High intensity and decorative type profile LED light complete with aluminium profile with cover , LED strip with driver etc and fixing the same with suitable adhesive, nails , making connections testing etc complete as reqd	RMT	0		
8.10	Supplying and fixing of inbuilt rope / Profile LED light complete with connectors at desired locations etc complete as reqd. (M/s Havells Make)	RMT	0		
TOTAL FOR LIGHTING FIXTURES					
9	TELEPHONE SYSTEM				
9.1	Wiring for telephone points with 2 pair 4/5 pair .51mm dia ATC (annealed tinned Cu wire) with PVC insulated PVC sheathed telephone cable from tag block to the point including providing ferrules at both ends and termination at both ends including providing & fixing RJ 11 outlet, faceplate and mounting box complete of modular type 9 where 2 such points are shown, 2 such wires shall be provided) This work includes providing PVC conduits in chases from the raceway to the point. (1 each for branch manager, C.C. P. officer & Clerck).	Nos.	5		
9.2	Supplying, laying effecting terminations, testing and commisioning of 0.51mm dia Cu. Conductor, twisted, colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing & fixing conduit pipe or cable tray as required from building tag block to the floor as required.				
9.3	1 X 10 pair armoured cable from telephone connection in the premises to the crone box.	rmt	30		
9.4	Supplying & fixing 20 pair krone tag block with enclosure.	Nos.	1		
10.	DATA SYSTEM - CONDUITING & CABLING				
10.1	providing and laying UTP Cat 6 data cable for nodes through 25mm dia PVC conduit through floor, wall and partitions etc including all necessary materials from main Hub to building tag block(BSNL) & Branch to ATM	rmt	120		

10.2	Wiring for computer networking from I/O hub to computer workstation with UTP Cat-6 computer cable including providing ferrules at both ends and termination at both ends including providing & fixing frame for with shutter, RJ 45 outlet, faceplate and mounting box complete of modular type, This work includes providing PVC conduits (1/2", 3/4" size or as required) in chases from the I/O hub to the point. The cost includes testing, commissioning etc complete. Note : Do not run more than 3 wire in single pipe & should be concealed. (2Nos of ATM)	Nos.	15		
10.3	Supply of Cat - 6 D-Link patch cord 7' 0" (ATM 1No)	Nos.	15		
10.4	Supply of Cat - 6 D-Link patch cord 3' 0"(ATM 1No)	Nos.	15		
10.5	Supply & fixing 24 Port Jack Panel Make:-D-Link	Nos.	1		
10.6	19" Rack 9U with Glass Door , Locking system Make: APW	Nos.	1		
10.7	24PORT 10/100Mbps Switch	Nos.	1		
	TOTAL FOR LAN AND DATA NETWORKING				
	TOTAL FOR ELECTRICAL WORK (B)				
	* GST EXTRA AS APPLICABLE				

ESTIMATE FOR AIR CONDITIONING WORKS AT INDIAN BANK, MODINAGAR

S. No.	Description	UOM	Qty.	Rate (Rs.)	Amount (Rs.)
	AIR CONDITIONERS				
1	Supplying, erection, testing and commissioning following wall mounted Split / Root mounted split/cassette units of with cordless remote complete with all necessary fittings duly insulated with 9 mm thick nitrile rubber pipe insulation with (All coils – copper only) , fan and fan motor, machine control panel improved Refrigerant Joints. Air conditioners shall be fitted with hermetically sealed type suction cooled reciprocating or discharge cooled rotary compressor or scroll compressor. Compressor unit operating on R32/ R-410. All complete as per drawing, approval and instructions of the Architect/ Employer (Rates to be inclusive of Copper refrigerant pipe with insulation and Drain pipe up to 3 Mtr length). Item to include powder coated outdoor stands as per the manufacturer specifications.				
a	2.0 TR wall mounted split unit (Minimum 5-Star rating inverter type) including all necessary fittings and mountings as specified by the manufacturer	Nos.	0.00		
b	1.5 TR wall mounted split unit (Minimum 5-Star rating inverter type) including all necessary fittings and mountings as specified by the manufacturer	Nos.	0.00		
c	1.0 TR wall mounted split unit (Minimum 5-Star rating inverter type) including all necessary fittings and mountings as specified by the manufacturer	Nos.	0.00		
2	EXTRA REFRIGERANT PIPING				
	Supplying and laying of Extra copper refrigerant piping with nitrile rubber pipe insulation, both of size as specified by the manufacturer suitable for 1.5 TR TR Split type AC and 2.0 TR TR Cassette AC (From Indoor to outdoor Units).				
a	For 1.0 TR/1.5 TR/2.0 TR Split AC as specified by the manufacturer	Mtr.	90.00		
b	For 1.5 TR / 2.0 TR Cassette AC as specified by the manufacturer	Mtr.	0.00		
3	DRAIN PIPING				

	Providing and fixing drain piping up to drain as directed by the engineer incharge with all accessories e.g. elbows, unions, sockets, reducers, reducing tees, nipples etc. Complete job including cutting chiseling in walls, floor and making good of all chases/cuts etc. and				
	discharging the drain into a floor trap/ gully as per site conditions with insulation, both as specified by the manufacturer.				
a	25 mm dia PVC drain pipe for Split AC	Mtr.	90.00		
b	32 mm dia PVC drain pipe for Cassette AC	Mtr.	0.00		
4	Providing and fixing Stabilizer with 3 step relay and input voltage range of 170-270 V and output to be 230 V (Blue bird/ Logic state/ Inline/ V-gourd) (copper winding).				
a	4 KVA (For 1.0 TR / 1.5 TR AC)	Nos.	2.00		
b	5 KVA (For 2.0 TR AC)	Nos.	4.00		
5	Supplying and laying of Extra Electrical interconnecting control cables from indoor to outdoor of size as specified by the manufacturer suitable for 15/2.0/3.0 TR Cassette type AC.	Mtr.	0.00		
6	Supplying and laying of Extra Electrical interconnecting control cable from indoor to outdoor of size as specified by the manufacturer suitable for 1.0TR/1.5TR/2.0 TR Split type AC.	Mtr.	150.00		
7	Providing and fixing of lockable caging (including stand) for outdoor unit grouted on wall or on roof with open able shutter made of 10 X 10 mm MS square bars placed vertically @ 5" c/c welded with 40 X 3 mm MS flat all- round. Item includes all necessary hardware, priming coat, synthetic enamel paint, hanger, clamps other accessories etc. All complete as per approval and instructions of the Architect/ employer.				
a	For 2.0 TR / 1.5 TR ceiling mounted cassette unit	Nos.	0.00		
b	For 1.0/1.5/2.0 TR Hi Wall split units	Nos.	6.00		
8	Supply, installation, testing and commissioning of Drain pumps minimum 2 litre hi flow tank with all fixing materials etc. all complete as per the directions of Architect/ Engineer-in-charge.	Nos.	0.00		

9	<p>Providing and fixing timer switch for switching power alternatively between two A/C, timer will be analogue dial type adjustable TIMER switch which is adjustable over 24hrs. With 15 minutes intervals and is to have 1NO+1NC (20A) contact. Timer will have its own backup battery and will be enclosed in 16gauge MS Box with acrylic lid together with suitable connector block. (ABB/MDS/L&T)</p>	Nos.	1.00		
10	<p>Removing, Repairing & Refixing Old Split IDU & ODU & STABLIZER & MS FRAME from existing location to proposed location. It include nessesary repair & filling coolent gas as required as per direction given by Architect.</p>	Nos.	0.00		
GRAND TOTAL					
<p>Note:- The rates quoted includes all discounts, other taxes , duties , loading, unloading , transportation, other expenses etc to site. only GST will be paid Extra.</p>					