

CORRIGENDUM -1

Date: 13.03.25

Tender NIT NO - ZO: EST: TNR: QTR: SHIVAM: 001: 2024-25 Dated 18-02-2025

Name of the work: REPAIRING & REVAMPING WORKS – INTERNAL & EXTERNAL (CIVIL,INTERIOR, PLUMBING & ELECTRICAL), INCLUDING STRUCTURAL RETROFITING & REPAIRING WORK AT SHIVAM RESIDENTIAL BUILDINGCOMPLEX, 1- FAKIR PARA ROAD, BEHALA, KOLKATA – 700 034

MINUTES OF PRE-BID MEETING held on 12.03.25, 16:00 Hr @ IB Office building, 14- India Exchange Place, Kolkata – 700 001

- I. No bidders/ contractors show up for the pre-bid meeting on the designated day.
- II. Architectural consultant signature consent on site visit form as per tender documents part-1 (Technical bid) Page-9 is mandatory for all bidders/ contractors as per tender guidelines.
- III. As per tender documents part-2 (Financial bid) cost abstract of amount to be quoted excluding GST. GST amount to be payable as per norms subject submission of proper GSTIN bill/ invoice.

CORRIGENDUM ITEM

AS PER NIT	TECHNICAL SPECIFICATION (Description of works)
Financial Bid – Electrical work (ITEM NO-1)	Supply and fixing GI pipe earth station conforming fully to IS 3043 with latest amendments, complete with 3m long 50mm Dia GI pipe (3mm Thickness, TATA B-class) with Funnel on Top with holes drilled for tapping connection. The rate includes making 300mm diameter pit and after excavation pit to be filled with to surface with alternate layer of salt/charcoal mixture. Brick work masonry shall be constructed of size 450x450x300 mm with RCC cover. Note: Test report of resistance of the new earth pit to be submitted.
Financial Bid – Electrical work (ITEM NO- 2)	DESITC of 25x3 mm GI Strip to be clamped on wall, cable tray, buried in ground to interconnect the earth electrodes mentioned above to the structures and power evacuation panel / combiner panel, lighting arrestor separately (The GI strip shall be printed with green print as per electrical inspectorate norms).

Note:

- a. Quantity for the above items will remain same.
- b. All other terms and conditions of tender will remain unchanged.
- c. Prospective bidders are requested to remain updated for any notices/ amendments/clarifications etc. to the e-tender through the website. No separate notification/ communication for such notices/ amendments/ clarifications etc. in the print media or individually.

-Sd/-

Yours faithfully,

CHIEF MANAGER – ADMIN
Estate Department
Zonal Office: Kolkata Central