



CORPORATE OFFICE
CHENNAI-14

PRE-BID QUERIES AND CLARIFICATIONS

TENDER FOR SITC OF 380 KVA DG SET

Sl.No.	Pre Bid Query	Reply/ Clarifications
1	DLP (24 Months) will commence from the date of testing, commissioning and handing over of Generators. Obtaining CEA approval should not be considered since it has to be obtained from the Government Department, which normally takes 6 – 8 weeks from the date of commissioning.	Tender conditions hold good.
2	We can complete supply, installation, testing, commissioning and hand over of 380 KVA Diesel Generator Sets within 60 days except CEA approval. CEA approval needs to be obtained from the Government Departments. The Government Officials have to inspect the Diesel Generators and will be issuing the CEA certificate, which may take even two months from the date of commissioning, since Government Officials will inspect the site only on the basis of their convenience. Therefore, for considering the Liquidated Damages, kindly consider only the time taken for commissioning and handing over of Generator Sets and not the time taken to obtain CEA approval, since it is beyond our control.	Waiver of LD may be considered based on the merits of the case.
3	Terms of Payment: 70% of the contract / interim bill value on receipt of materials at site and against submission of invoice, duly certified by Indian Bank / Consultant subject to deduction of 5% towards retention money. OK. 20% of the contract value should be released immediately after testing, commissioning and handing over of Diesel Generator Set subject to deduction of 5% towards retention money. Balance amount (10%) should be released after obtaining CEA certificate.	Tender conditions hold good.
4	The Generator offered by the tenderer will be tested on 50% load, 75% load and full load, totally for 8 hours at the factory. No load and 25% load testing is not advisable as per our principal's information.	Tenderer's condition for waiver of testing of DG Set at "No" load and 25% load waived. However, with regard to testing at other loads (above 25%) at the factory test bed, tender conditions under 51-2 shall hold good
5	The tenderer can arrange to depute a Senior Operator to the site of works to operate the DG Set for a minimum period of 7 days after successful installation, for which diesel and consumables needs to be arranged by you.	The testing of DG set at the site on load is restricted to 5 days instead of 7 days. Other Tender conditions in this regard shall hold good.

6	Fuel Oil System: MS Fuel Line Connection not required since Fuel Tank is kept inside KG Canopy.	Can be accepted.
7	Alternator terminal box suitable for 2 runs of 3.5 Core X 300 sq.mm PVC insulated Aluminium Armoured Cable.	Tender Conditions shall hold good.
8	Instead of individual digital meters viz., Digital type Ammeter, Voltmeter, Frequency Meter, KWH Meter, Single Unit KG545 will be supplied along with DG Set, incorporating the features of above matters – Literature enclosed.	Can be accepted.
9	KG Canopy for housing the DG Set will be supplied. The guaranteed noise level shall be 75 decibals at 1 mtr distance under free field conditions.	Can be accepted.
10	The Generator Sets which are offering is as per CPCB norms and not as per BHARAT III / IV Euro III Emission standards.	Shall Confirm to CPCB / SPCB norms
11	Power Cable from alternator to control panel viz., 2 runs X 3.5 Core 300 sq.mm PVC insulated armoured Aluminium cable will be provided as per BOQ.	Tender conditions shall hold good.
12	Operating tool kits is not provided along with engine, hence operating tool kits will not be provided.	Can be accepted.
13	Bank Guarantee: Not possible for Annual Maintenance Contract.	Tender conditions hold good.
14	We have to bring the Generator in dismantled conditions. Present opening available is only 6 feet, not possible bring the Generator, we require 8 feet opening to bring the Generator in dismantled conditions, necessary provisions in this regard needs to be done by you.	Required clearance will be arranged.
15	What are the testing to be carried out at site.	Please refer clause 51 of General Conditions of Contract of Tender Documents and also the BOQ
16	Which tests are possible shall be carried out.	Please refer clause 51 of General Conditions of Contract of Tender Documents and also the BOQ
17	Engine testing certificate will be issued.	Can be submitted by the tenderer for approval by Bank / Consultant.
18	Foundation Drawing and Standard Panel drawing are available	The drawings shall be submitted for approval by Bank/ Consultant vide clause 4 General Conditions of Contract
19	Instead of individual Meters Multifunction Meter will be supplied.	Accepted.
20	CEA Inspection should not be counted for completion of work and LD for delay not acceptable.	Waiver of LD can be considered based on the merits of the case.
21	Operating tools are not supplied with DG sets.	Can be accepted.

22	<p>Payment terms have to be altered.</p> <ul style="list-style-type: none"> a. Payment for the DG set 80 % on arrival at site. b. Payment of 20 % of th DG value to be paid against Bank Guarantee. c. Payment for the erection items :70% on arrival of material at site d. Payment on completion of erection: 20% <p>Payment against bank guarantee: 10 %</p>	Tender conditions hold good.
23	Proof of application to CEA to suffice. Time frame for certification from a Govt. Body is not in our purview.	Tender conditions hold good.
24	Testing trials at factory should be limited to four hours. All material is type tested and is sourced from ISO organizations. The company is also accredited ISO.	Tender conditions hold good.
25	Load trials at bank can be limited to 8 hours or one full working day.	Please Refer point no 5 of above
26	In view of traffic restrictions work must be allowed unhindered through the day and night.	Refer tender conditions 12,21 and 49 of General Conditions of contract.
27	One work supervisor from client side to be allocated at site exclusively for this project.	Will be arranged
28	The price quoted for the removal of the old generator will be treated as sale and invoice for the same with applicable taxes will be raised in favor of the bank.	Tender conditions hold good.

Note: All the tenderers are once again requested to visit the site before quoting